

UNLICENSED ELECTRICITY GENERATION IN THE ELECTRICITY MARKET REGULATION

Reasonable efforts have been made in order to provide accurate translations. Translations are provided to users of EPIAŞ website, "as is." No warranty of any kind, either expressed or implied, is made as to the accuracy, reliability, or correctness of any translations made from Turkish into English.

Purpose

ARTICLE 1¹ – (1) The purpose of this Regulation is to set out the procedures and principles that apply to the individuals and legal entities, who are entitled to generate electricity without the need to obtain license and to establish a company, for the purposes of enabling consumers to meet their electricity requirements from their generation facilities, incorporating the small scale generation facilities to the national economy for supply security and ensuring the efficient use of the small scale generation resources.

Scope

ARTICLE 2 – (1) This Regulation covers the procedures and principles regarding;

(a) Principles and procedures relating to the connection of generation facilities to be established within the scope of the Article 14 of Electricity Market Law No. 6446 to the system and evaluation of applications for the establishment of such generation facilities;

(b) Practices to be implemented in the event that individuals and legal entities engaged in unlicensed generation activities transmit the surplus electricity they generate to the system;

(c) Rights and obligations of individuals or legal entities and relevant network operators engaging in generation and transferring of generation facilities related to the unlicensed generation;

(ç) Supervision of activities within the scope of this Regulation of persons who engage in unlicensed generation and supervision of established electricity generation facilities.

Legal basis

ARTICLE 3 – (1) This Regulation is based on Article 14 of the Electricity Market Law numbered 6446 and dated 14/03/2013, and on Article 6/A of the Law on the Utilization of Renewable Energy Resources for the Purpose of Generating Electricity numbered 5346 and dated 10/05/2005.

Definitions and abbreviations

ARTICLE 4 – In implementation of this Regulation, the following definitions shall apply:

- (a) Isolation: Physical separation of a part of distribution system with generation facility from distribution system in a way that will keep that part energized;
- (b) AG: Voltage level with effective power of 1000 Volts or less;
- (c)²Contract power set out in the connection agreement: Power calculated by multiplying the installed capacity referred in the electricity project of a place of use with the utilization factor; the installed capacity for users on single tariff with a private transformer is to be multiplied by 0.60; and the requested capacity for users subject to the dual tariff as calculated by taking $\cos \varphi = 1$, or the power value specified in the connection agreement for the transmission system;

¹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

² Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

- (ç) Ministry: The Ministry of Energy and Natural Resources;
- (d) Cogeneration facility within the scope of this Regulation: Cogeneration and tri-generation facilities meeting the productivity levels designated by the Ministry;
- (e) Consumption Facility within the scope of this Regulation: Units, facilities and equipment consuming electricity, under the responsibility of individuals or legal entities or within the scope of the consumption aggregation either connected to the distribution or transmission system or to be connected to a generation facility in accordance with the connection agreement or connected to a distribution or transmission system within the scope of an existing agreement executed before 25/09/2002;
- (f) Distribution region: Region defined in the license of the a distribution company or distribution license holder OIZ;
- (g) DSİ: General Directorate of State Hydraulic Works;
- (ğ) EİGM: Ministry General Directorate of Energy Affairs;
- (h) Invoicing period: Period commencing from 00.00 of the first day of a calendar month until the beginning of the following calendar month;
- (ı) ³Special Provincial Administration: Special provincial administration of the place where the generation facility will be established or in the absence of special provincial administrations, Monitoring and Coordination Presidency of the relevant Governorate;
- (i) ⁴Relevant legislation: Laws, Presidential decrees, Presidential decisions, regulations, communiqués, circulars and Board decisions relating to electricity market;
- (j) Other relevant legislation: Regulations, communiqués and other legislation issued by Presidency and Ministries;
- (k) Relevant standard: TS, EN, IEC, ISO standards and other international standards in order of priority relating to the equipment, connection system and performance criteria to be used in the generation facility;
- (l) Relevant network operator: TEİAŞ, distribution company or legal entity holding distribution license depending on the relevance;
- (m) Relevant technical legislation: Regulation, communiqués and other legislation issued by the Ministry;
- (n) Permanent data custodian: Text messages, electronic mail, internet, disk, CD, DVD, memory card and any other means and media that enables data sent by the consumer or sent to the customer to be recorded and copied without modification in a way that allows this information to be examined in accordance with this purpose;
- (o) Law: Electricity Market Law dated 14/3/2013 and numbered 6446;
- (ö) Offsetting: The process of finding the net generation or net consumption value in kWh as a result of deducting the generation and consumption from each other within a certain period of time;
- (p) Micro-cogeneration facility: A cogeneration facility based on electricity with an installed capacity of 100 kilowatts or less;
- (r) OG: Voltage level with efficient power over 1000 V and up to 36 kV (36 kV included);
- (s) Market operator: Energy Markets Operator Company of Turkey;
- (ş) Network: Transmission, distribution or OIZ distribution network depending on the connection points of the consumption facility within the scope of this Regulation;
- (t) ⁵Technical evaluation report: Report prepared as a result of the evaluation made by EİGM based on geothermal, biomass, wind or solar energy-based generation applications;

³ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁴ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁵ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

(u) Technical interaction permit: Positive or conditional wind turbine installment permit granted to the relevant persons by relevant institution through Ministry as a result of the technical interaction analysis;

(ü) ⁶YEKDEM: A support mechanism that includes the prices, periods, and the procedures and principles of payments that legal entities engaged in generation activities by holding a generation license directly or through an aggregator based on renewable energy resources within the scope of the Regulation on the Certification and Support of Renewable Energy Resources published on the Official Gazette dated 01/10/2013 and numbered 28782 can benefit on their own and that persons who are generating electricity based on the renewable energy resources within the scope of this Regulation can benefit through distribution companies assigned in their regions or aggregator;

(v) ⁷Renewable energy resources: Non-fossil energy resources such as hydraulic, wind, solar, geothermal, biomass, waves, current and tide;

(y) YEK Law: Law on the Utilization of Renewable Energy Resources for the Purpose of Generating Electricity No. 5346 and dated 10/5/2005;

(z) YG: Voltage level with efficient power over 36 kV;

(aa) ⁸Relevant Period: The period between the dates when the breach defined in the Regulation starts and ends (including the start and end dates),

(bb) ⁹YEPDİS: The Renewable Energy Resources Evaluation and Monitoring System that contains the information requested by EİGM and is operated by EİGM,

(2) Within the scope of this Regulation, generation facility and consumption facility will be regarded in the same place if the connection of the generation facility is built to the consumption facility side before bidirectional meter.

(3) Other expressions and abbreviations in this Regulation shall have the meanings ascribed to them in the relevant legislation.

Exemption from obtaining license and establishing company

ARTICLE 5 – (1) Generation facilities exempt from the requirement to obtain a pre-license and license or to incorporate a company are as follows:

(a) Emergency generator sets;

(b) ¹⁰Generation facilities that work isolated without being connected to the transmission or distribution systems;

(c) Generation facilities based on renewable energy resources with installed capacities of maximum one megawatt or maximum megawatt to be designated by the President in accordance with the Article 14 of the Law;

(ç) Generation facilities based on renewable energy resources using all of the energy they generate without supplying any of it to the transmission or distribution systems, and whose generation and consumption are at the same metering point;

(d) Cogeneration facilities in the category providing the efficiency value to be determined by the Ministry;

(e) Micro-generation facilities;

(f) Waste water treatment facilities of municipalities and generation facilities used for the disposal of sludge from wastewater treatment;

(g) Energy generation facilities established on water conveyance lines and waste water conveyance lines by legal entities, of which more than half of the capital directly or indirectly

⁶ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁷ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁹ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁰ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

belongs to the municipality, provided that there are technical means and if it is approved by the DSI;

(ğ) ¹¹Generation facility based on renewable energy resources established and operated by the General Directorate of State Hydraulic Works or by irrigation unions upon approval of General Directorate of State Hydraulic Works in order to meet the electricity needs of agricultural irrigation facilities, the electricity subscriptions of which is in the name of the General Directorate of State Hydraulic Works or irrigation unions, provided that the installed capacity of these generation facilities is limited to the contract power set out in the connection agreement of the agricultural irrigation facility and if there are multiple facilities, the total contract power of all of these facilities;

(h) ¹²Generation facility based on renewable energy resources established at either the same or different metering point as the consumption facility, provided that they are limited to two times the contract power set out in the connection agreement in the case of municipalities and affiliated institutions as well as industrial facilities and agricultural irrigation facilities, and that they are limited to the contract power set out in the connection agreements in the case of other persons.

(ı) ¹³ Generation facilities based on renewable energy resources established at either the same or different metering point upon the General Directorate of State Hydraulic Works' affirmative opinion and operated by irrigation unions on immovable property which irrigation unions are responsible for the operating, maintenance, repair and management of, as well as other immovable property which are under the ownership or disposal of irrigation unions and the General Directorate of State Hydraulic Works, provided that they are established limited to the contract power set out in the connection agreements.

(i) ¹⁴Generation facilities to be established by legal entities incorporated by special provincial administrations on the water source of the network used solely for irrigation as well as irrigation network with pressure piping or classic canal which are operated by special provincial administration, provided that it is technically feasible and such establishment is approved by DSI.

(2) In the event that the surplus electricity output generated by individuals and legal entities who generate electricity based on renewable energy resources and who are exempt from the obligation to obtain a pre-license and license are supplied to the system, this electricity shall be considered within the scope of YEKDEM through the related supplier company.

(3) Transactions relating to the water usage rights of generation facilities within the scope of sub-paragraph (g) of the first paragraph shall be finalized in accordance with water usage right procurement legislation.

(4)¹⁵ Within the scope of this Regulation, establishment of more than one generation facility based on renewable energy resources for one consumption facility and/or more than one cogeneration facility in one metering point with the same offsetting and support structure may be granted permission provided that there is enough capacity in the distribution and/or transmission system. For each consumption facility, installed capacity of generation facility or facilities based on renewable energy resources to be established in accordance with sub-paragraph (c) of the first paragraph cannot be more than maximum capacity referred in the sub-paragraph (c) of the first paragraph. An individual or legal entity can establish only one microgeneration facility for each consumption facility under its responsibility.

¹¹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹² Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹³ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁴ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁵ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920..

(5)¹⁶ It is compulsory for individuals and legal entities that will establish generation facilities in accordance with this Regulation to have their generation facilities and consumption facilities in the same distribution region. Nevertheless, within the scope of sub-paragraph (h) of the first paragraph of Article 5, a generation facility may be established outside the distribution license region where the consumption facility is located.

(6)¹⁷ Installed capacity upper limit shall not apply to generation facilities falling under sub-paragraph (a), (b), (ç), (d), (f), (g), (ğ), (h), (i) and (i) of the first paragraph.

(7) Within the scope of this Regulation; general provisions to be included in the connection and system usage agreements to be executed with generators who will connect to the network shall be designated by the Authority. Designated general provisions shall be announced on the web site of relevant network operator and the Authority.

(8)¹⁸ Additional generation facility or facilities can be established within the scope of sub-paragraph (h) of the first paragraph, on the condition that the offsetting processes are carried out in accordance with Article 26, the invitation letter for the connection agreement has been issued within the scope of sub-paragraph (c) of the first paragraph, the connection agreement is signed or the consumption facilities associated with the generation facilities whose acceptance procedures are completed.

(9)¹⁹ Transition may be made to sub-paragraph (h) of the first paragraph by way of associating the consumption facilities located at different metering points provided that the existing consumption facilities associated with generation facilities, whose offsetting processes are carried out in accordance with Article 26 and for which a connection agreement invitation letter is issued, a connection agreement is signed or whose acceptance procedures are completed within the scope of sub-paragraph (c) of the first paragraph, remain stable.

(10)²⁰ A request for increase in installed capacity may be made within the scope of sub-paragraph (ç) of the first paragraph for generation facilities whose offsetting processes are carried out within the scope of Provisional Article 1 and Provisional Article 4 and in accordance with Article 26 and for which a connection agreement invitation letter is issued, a connection agreement is signed or whose acceptance procedures are completed within the scope of sub-paragraph (ç) of the first paragraph.

Transactions within the scope of relevant technical legislation

ARTICLE 6 – (1) Project designing, installation, connection to the system, acceptance, operation, maintenance and testing and trial activities of generation facilities within the scope of this Regulation shall be conducted in compliance with the applicable standards and in a way as defined in the relevant technical legislation.

(2) Owner of the generation facility shall comply with issues in first paragraph and conditions required by relevant technical legislation and relevant standards.

(3) In regards to the generation facilities that do not meet the conditions required by the relevant technical legislation and relevant standards:

(a) In the event of risky situations that are substantial or dangerous in terms of life and property safety or affecting electricity system safety, generation facility shall be separated from network without the need for a notice until it is made suitable again and grounds for separation shall be notified to the owner of the generation facility in 3 (three) business days in writing;

(b) In the event of situations that are not substantial in a way not affecting the operation of the system or the generation facility and safety of the installation and not dangerous in terms of life and property safety and not affecting the safety of electricity system, if the violation is

¹⁶ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁷ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹⁹ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

²⁰ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

not remedied within 15 days from the notice requiring that the violation be remedied by the relevant network operator, generation facility shall be separated from the network by the network operator. If said violation is remedied, generation facility shall be reconnected to the system and put into operation in 3 (three) business days.

(4) In the event of short circuit fault or network lacking energy, in order to ensure the safety of life and property, generation facility shall be isolated from network in respect of connection point and shall not be supplied energy. Isolation in a way to include a part of the network shall not be permitted. In this case, the generation facility, which is isolated from the network in respect of the connection point, may supply isolated part of the consumption facility independently from the network.

Connection principles

ARTICLE 7 – (1) Generation facilities within the scope of this Regulation shall be connected to the distribution system save for the exceptions under the fourth paragraph. Relevant network operator may connect the generation facility to the distribution system from OG or AG level depending on the characteristics and current capacity of distribution system in respect of the connection point. Request for connection application may be refused only in accordance with the relevant legislation and relevant technical legislation and grounds for refusal shall be notified to the applicant in writing along with the refusal decision.

(2) ²¹Total capacity of generation facilities to be connected from AG level, may not exceed fifty per cent of the transformer power, if the distribution transformer to which these generation facilities are connected is owned by the relevant network operator. If the transformer is owned by the applicant, said capacity shall be equal to the maximum transformer power. A generation facility application can be made up to the maximum transformer power for distribution transformers that are installed for consumption facilities of persons engaged in a specific business field only and cannot be utilized by any outside individuals or legal entities or those that are pertaining to industrial zones.

(3) ^{22,23}Except for the applications for generation facilities established for consumption facilities pertaining to persons that fall within the scope of the first paragraph the Article 11 and persons engaged in a specific business field only, and which cannot be utilized by any outside individuals or legal entities or which are connected to the system from distribution transformers pertaining to industrial zones, capacity of a distribution transformer owned by a network operator that can be allocated to a person in one calendar year shall be designated in accordance with table in the Annex-3.

(4) Under the first paragraph of Article 5;

(a) Generation facilities to be established within the scope of sub-paragraph (ç), provided that the consumption facility to be associated with these facilities is connected to the system at transmission level,

(b) Cogeneration facilities to be established within the scope of sub-paragraph (d),

(c) ²⁴Depending on its installed capacity or provided that the consumption facility is connected to the system at the transmission level in installations located at the same metering point, facilities based on renewable energy resources to be established within the scope of sub-paragraph (h) shall be connected to the transmission system. For applications for the generation facility to be connected to the transmission system within the scope of this paragraph, the works and transactions stipulated to be carried out by the distribution company in the generation

²¹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

²² Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

²³ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

²⁴ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

facility applications to be connected to the distribution system in this Regulation shall also be carried out by TEİAŞ.

(5)²⁵ Following the evaluation of applications for generation facilities to be established in terms of documentation requirements, TEİAŞ shall be consulted regarding the fault current limit specific to the transformer station. TEİAŞ shall conclude the consultation request within fifteen (15) days from the date of receipt of the request.

(6)²⁶ In the event that it is notified by TEİAŞ that the fault current limit is exceeded in relation to the relevant transformer station and/or the nominal apparent power without forced cooling of the transformer in the relevant transformer station is exceeded, applications for the relevant transformer station shall be refused without any further process.

(7)²⁷ Except for the generation facilities to be established under sub-paragraph (h) of the first paragraph of Article 5 from the transmission level, if the provisional acceptance of transformer station, distribution center, energy transmission line on the connection point and distribution facilities including the transformer pertaining to the consumption facility for persons with private transformers has not been made, no application can be made within the scope of this Regulation. Applications made shall be refused without any further process.

(8)²⁸ Except for the generation facilities to be established under sub-paragraph (h) of the first paragraph of Article 5 from the transmission or distribution level with an installed capacity of 10 MW and above, for the generation facilities to be established within the scope of this Regulation, direct connections and feeder allocations cannot be made, save for the exceptions defined under the fourth paragraph.

(9) The generation facility to be established within the scope of this Regulation cannot be connected to any other distribution system located outside the distribution area where the said generation facility will be established.

(10)²⁹ Installed capacity of the generation facilities to be established within the scope of the sub-paragraph (c), (f), (ğ) and (i) of the first paragraph of Article 5 cannot be more than the contract power set out in their connection agreements of the consumption facility that will be related to the relevant generation facility.

(11) In the event that opinion for connection is granted to the generation facilities and/or consumption facilities that are not related to the unlicensed generation facility through facilities that were consolidated before 23/03/2016 or for those made exclusively for unlicensed generation facilities within the scope of the given connection opinion and not purchased as of 17/1/2018 by the network operator and qualifying as distribution facilities even if single, the network operator shall purchase the common use parts of those facilities for a nominal fee in accordance with the Electricity Market Connection and System Usage Regulation published on the Official Gazette dated 28/1/2014 and numbered 28896.

(12)^{30,31} Except for provisional subscriptions of consumption facilities under construction, individuals or legal entities cannot establish generation facility within the scope of this Regulation for the consumption facilities within the scope of the provisional connection. However, consumption under provisional subscriptions may be included in offsetting with production facilities belonging to the same individuals or legal entities and in the same subscriber group.

²⁵ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

²⁶ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

²⁷ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

²⁸ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

²⁹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

³⁰ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

³¹ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

(13) Connection agreement shall be amended as a result of the amendments made on the generation facility in accordance with the relevant legislation provisions pertaining to the connection and system usage.

(14)³² If the owner of the generation facility seeks to make other changes, including increasing or decreasing the DC/AC power of the generation facility, changing the protection scheme, changing the compensation, it is obliged to apply to the relevant network operator in advance and obtain permission in accordance with the procedures stipulated in the relevant legislation. In applications based on wind or solar energy; the information in the technical evaluation form to be submitted regarding the change shall be sent to the EİGM for technical evaluation by submission through YEPAİS.

(15)^{33,34} Unlicensed generation application cannot be made save for the subparagraph (b) of first paragraph of Article 16 and the eighth paragraph of Article 30 and the provisions of relevant legislation for generation facility sites subject to pre-license sites or generation license application, in such case relevant applications shall be returned.

(16) For the generation sites subject to the unlicensed generation application;

(a) In the event of a solar energy-based or wind energy-based pre-license applications, if technical evaluation conducted by EİGM for each application is positive, such applications shall be concluded in accordance with the provisions of relevant legislation. If relevant applications adversely impact each other as a result of the technical evaluations conducted by EİGM, applications for unlicensed generation shall be refused except for the ones that received invitation letter to sign connection agreement. In the event that the unlicensed generation application is entitled to receive an invitation letter to sign connection agreement, pre-license and license applications shall be refused if there is no possibility of revision;

(b) In the event that a pre-license or license application is made based on resources other than wind or solar energy and the application for unlicensed generation does not qualify for an invitation letter for the connection agreement, the application for unlicensed generation shall be rejected;

(c) In the event of pre-license or license applications based on resources other than wind or solar energy and in the event that unlicensed generation application is entitled to receive invitation letter, relevant pre-license and license application shall be refused and unlicensed generation applications shall be concluded in accordance with the provisions of relevant legislation. However, if the pre-license application made at the same day for the establishment of generation facilities in the relevant generation sites is entitled to receive invitation letter to sign connection agreement and an application for pre-license and license is made, unlicensed generation application shall be rejected;

(17)³⁵ For the investments of distribution facilities and/or transmission facilities belonging to generation facilities to be established within the scope of sub-paragraph (h) of the first paragraph of Article 5, the process shall be established in accordance with the provisions of the Electricity Market Connection and System Usage Regulation.

(18)³⁶ In case the persons defined in sub-paragraph (h) of the first paragraph of Article 5 intend to establish a generation facility at the same metering point and up to two times the contract power specified in their connection agreement, a request for power increase may be made in transformers, provided that the contract power specified in the feed-in connection agreement remains constant for persons with private transformers.

³² Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

³³ Amended pursuant to the Regulation published in the Official Gazette dated 02 March 2023 and numbered 32120.

³⁴ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

³⁵ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

³⁶ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

(19)³⁷ TEİAŞ shall announce on its website the information regarding the connection capacity of each transformer station within the first fifteen days of each month in the format to be prescribed by the Board.

(20)³⁸ Following the announcement made by TEİAŞ within the scope of the nineteenth paragraph, distribution companies and OIZ distribution license holder legal entities in the relevant distribution region, shall announce on their own websites information regarding connection opinions given and generation facility applications made within the scope of this Regulation, including those that fall within the scope of licensed generation, until the twenty-fifth day of each month in the format to be prescribed by the Board.

Emergency generator sets and isolated generation facilities

ARTICLE 8 – (1) Individuals and legal entities seeking to generate within the scope of sub-paragraph (a) and (b) of the first paragraph of Article 5 shall notify the network operator. No document shall be issued for applications of these people within the scope of this Regulation.

(2) Business and transactions regarding generation facilities within the scope of sub-paragraph (a) and (b) of the first paragraph of Article 5 shall be carried out by the Ministry or an institution authorized by the Ministry.

Obtaining water usage right in generation facilities based on hydraulic resources

ARTICLE 9 – (1) In order to obtain water usage right for generation facilities based on hydraulic resources, an application shall first be made to the special provincial administration of where the facility is to be established. The individual or legal entity applicant is obliged to add the documents required in the legislation issued by DSİ to the application file.

(2) Special provincial administrations shall send connection applications received each calendar month within first five days of the following month to the authorized regional directorate of DSİ in order to obtain its opinion regarding the convenience of generation facility establishment in terms of water regime. Relevant DSİ unit shall conclude the convenience opinion in terms of water regime until twentieth day of the following month of arrival month and send it to special provincial administration. In the event that the opinion sent by the relevant unit of DSİ is positive, special provincial administration shall send this opinion to the applicant within the first five days of the following month of arrival month.

Applications

ARTICLE 10 – (1)^{39, 40} Individuals and legal entities that seek to engage in electricity generation within the scope of sub-paragraphs (c), (ç), (d), (e), (f), (g) (ğ), (h), (ı) and (i) of the first paragraph of Article 5 shall apply to the relevant network operator electronically along with information and documents designated by the Board decision. Documents shall not be returned in the case of applications submitted electronically.

(2) Relevant network operator cannot reject the application based on the absence of information and document other than those designated by the Board decision, save for other obligations arising from other relevant legislation.

(3) In the event that individuals or legal entities applying within the scope of this Article make a written request for a change in installed capacity related to the relevant generation facility within the month of the application,

(a) Installed capacity change request date shall be regarded as application date;

³⁷ Inserted pursuant to the Regulation published in the Official Gazette dated 29 July 2023 and numbered 32263.

³⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 29 July 2023 and numbered 32263.

³⁹ Amended pursuant to the Regulation published in the Official Gazette dated 29 July 2023 and numbered 32263.

⁴⁰ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

(b) Document to be submitted in accordance with the new installed capacity shall be submitted along with the application.

(4) In the event of a request of applicants, data that may be used in the application and that may be obtained from network operators by nature shall be provided in writing by the relevant network operator to the applicant within 3 (three) business days provided that a written request is submitted.

(5)⁴¹ In the event of transfer of a generation facility or facilities pursuant to subparagraph (h) of the first paragraph of Article 5, except in cases of inheritance or bankruptcy, no new application shall be submitted under this Regulation for the associated consumption facility or facilities linked to the transferred generation facility or facilities. Any application for an invitation letter within this scope for a connection agreement submitted by linking the relevant consumption facility or facilities shall be returned without evaluation. However, the provisions of this paragraph shall not apply in cases where the generation facility and its associated consumption facility are transferred together to the same person, or in transfers between public institutions and organizations and their affiliated or subsidiary entities.

(6)⁴² For the purposes of the implementation of the fifth paragraph, transfers executed within the same month shall be reported by the relevant network operators to the market operator no later than the fifteenth day of each month, to be announced by the market operator.

(7)⁴³ If an invitation letter for a connection agreement has already been issued to persons falling within the scope of the fifth paragraph, the procedure specified under the fourth paragraph of Article 34 shall apply.

Facilities that may apply

ARTICLE 11 –⁴⁴(1) In the evaluation of applications and utilization of surplus energy of generation facilities of which preparation of preapproved template projects up to 25 kW (including 25 kW) is approved by Ministry or institution authorized by the Ministry within the scope of this Regulation, and are based on renewable energy resources and up to its contract power set out in the connection agreement in its own consumption facility whose consumption and generation are connected at the same point, procedures and principles designated by the Authority and form of invitation letter to sign connection agreement shall apply. Applications for generation facilities based on the renewable energy resources within the scope of this Regulation shall be evaluated in accordance with the procedures and principles to be designated by the Authority.

(2)⁴⁵ Public institutions and organizations may establish generation facility based on renewable energy resources at the same metering point with consumption facilities within the scope of sub-paragraph (c) of the first paragraph of Article 5, provided that it does not exceed the contract power set out in the connection agreement of wastewater and drinking water treatment facilities and agricultural irrigation facilities.

(3) Individuals seeking to operate within the scope of this Regulation can establish a generation facility based on renewable energy sources without equipping a facility as a distribution facility at the same metering point as the consumption facility, not exceeding the contract power in the connection agreement and the installed capacity to be determined in accordance with sub-paragraph (c) of the first paragraph of Article 5. Solar energy based generation facilities can only be realized as roof and front applications.

(4) Generation facility for the purpose of agricultural irrigation on a part of agricultural land may be established within the scope of this Regulation, subject to the provisions of other

⁴¹ Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁴² Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁴³ Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁴⁴ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁴⁵ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

relevant legislation. However, installed capacity of the relevant generation facility cannot be more than contract power set out in the connection agreement of such irrigation facility. In this context, it is compulsory to submit the Approval Certificate issued by the DSI in accordance with the secondary legislation along with the applications. Applications within the scope of this paragraph shall be evaluated in accordance with the sub-paragraph (ç) of the first paragraph of Article 5.

(5)⁴⁶ In unlicensed generation applications where pyrolytic oil and pyrolytic gas, which are by-products resulting from the processing of waste tires, are planned to be used as fuel, the fuel in question shall be generated in the relevant electricity generation facility and no other resources shall be utilized.

Establishment of the commission

ARTICLE 12 – (1) Relevant network operator shall perform examination of the applications, except for the ones within the scope of the first paragraph of Article 11, in terms of documentation requirements and technical aspects through a commission to be established by compiling. Applications within the scope of the first paragraph of Article 11 shall be evaluated and concluded by the relevant network operator.

(2)⁴⁷ Commission of the distribution companies consists of one representative each from TEİAŞ, TEDAŞ and the relevant network operator and takes decisions with the majority of votes. President of the commission is the representative of TEİAŞ. In the event that the relevant network operator is a legal entity holding an OIZ distribution license, the commission shall consist of three members, including the OIZ manager, an expert staff from the regional distribution company, and an expert staff from the OIZ and shall take decisions by majority vote. Decisions adopted by the commission shall be executed by the members and preserved in the relevant files.

(3)⁴⁸ For unlicensed generation applications to be made at the transmission level, the commission shall consist of 3 members, all of whom are representatives of TEİAŞ, and take decisions by majority vote. Decisions taken by the commission are signed by the members and kept in the relevant files.

Evaluation of applications in terms of documentation requirements

ARTICLE 13 – ⁴⁹(1) New applications of individuals or legal entities seeking to generate within the scope of this Regulation received in each calendar month shall be evaluated and concluded in terms of documentation requirements collectively by the commission within first twenty days of the following month. Applications of those who submitted incomplete or incorrect documents shall not be taken into technical evaluation.

(2)⁵⁰ The applicant shall be notified about the nature of the incompleteness or incorrectness within 3 (three) business days following the evaluation results, and application documents shall be returned to the applicant after a copy of them is transferred to the permanent data storage, and the relevant provincial administration shall be informed about the issue in terms of hydraulic resources.

(3) Results of the examination in terms of document requirements shall be announced on the website of the relevant network operator in a way to include explanations about the incomplete and incorrect applications within the following business day of evaluation date.

⁴⁶ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁴⁷ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁴⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁴⁹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁵⁰ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

(4)⁵¹ Within the scope of this Regulation, new applications received within each calendar month of individuals or legal entities who seek to make generation by connecting at the transmission level shall be evaluated and finalized collectively in terms of documents within the first twenty days of the following month by the commission defined in the third paragraph of Article 12. Applications of those who submit incomplete or incorrect documents will not be taken into technical evaluation. Application documents shall be returned to the applicant after a copy is transferred to the permanent data custodian, by notifying the applicant about the nature of the incompleteness or incorrectness within 3 (three) business days following the evaluation results. The results of the evaluation made in terms of documents are published on the website of TEİAŞ, including explanations for incomplete and incorrect applications, within the business day following the evaluation date.

Technical evaluation of applications

ARTICLE 14 – (1)⁵² Applications found to be complete shall be evaluated by the commission in terms of technical aspects within the twenty days of the month following the month in which the evaluation was made. Applications for which TEİAŞ has notified that the fault current limit and/or nominal apparent power without forced cooling of the transformer in the relevant transformer station is exceeded shall be refused without technical evaluation.

(2) Applications shall be classified according to the transformer stations.

(3)^{53,54} Each application shall be evaluated independently in terms of connection and system usage but collectively in terms of connection point. Technical evaluation shall be completed by considering the transmission or distribution network congestions at the relevant connection point, by virtue of an evaluation of facility to be established in terms of measurement and preservation systems based on the conformity of the application to this Regulation, relevant technical legislation and relevant legislation. For applications other than those based on wind and solar energy, a positive connection opinion shall be issued provided that the technical evaluation conducted for establishing the connection opinion under this Article is deemed appropriate, regardless of the capacity announcements published by TEİAŞ. In addition, the provisions of the sixth paragraph shall likewise apply in the technical evaluation of applications other than those based on wind and solar energy submitted within the same month, where more than one application exists and the nominal apparent power rating of the transformer without air-cooling at the relevant substation proves insufficient for the combined capacities of such applications. However, if TEİAŞ has announced capacity for wind and solar energy applications and applications based on wind or solar energy and other resources are submitted in the same month, priority shall be given to wind or solar based applications within the scope of the capacity announced by TEİAŞ.

(4)⁵⁵ Following the technical evaluation results, applications are taken into priority evaluation, if applicable. Within the scope of the priority evaluation, applications shall be concluded considering the transmission or distribution network constraints in respect of connection point, if any.

(5) Applications not subject to connection constraints in respect of connection point shall be concluded without subjecting the technical evaluation results to priority evaluation.

(6)⁵⁶ During the priority evaluation to be implemented to the connection of wind or solar energy based generation facility that will be connected to the network by the relevant network operator, the following criteria shall be applied respectively;

⁵¹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁵² Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁵³ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁵⁴ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁵⁵ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁵⁶ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

(a) Generation facility subject to the application be located at the same metering point as the consumption facility planned to be associated with it;

(b) If the applicant has not previously received an invitation letter for the same consumption facility, the consumption amount for the last year must be higher than that of other applications based on the priority assessment determined in accordance with the ninth paragraph; if the applicant has previously received an invitation letter, the consumption amount must be higher than that of other applications based on the priority assessment determined in accordance with the ninth paragraph, excluding those that have been canceled;

(c) Contract power set out in the connection agreement of applicant to be more than other applications;

(ç) The applicant does not have an application for which a positive connection opinion has been given before.

(d) The annual consumption of the consumption points that do not have a one-year consumption is calculated on an annual basis, taking into account the average of their current monthly consumptions; if consumption is only for one month, it is calculated on an annual basis taking this consumption into account. In the applications made for the consumption points that do not have a monthly consumption and for the facilities in the construction phase, the calculation is made according to the consumption of the nearest similar consumption points, taking into account the project values. If more than one application meets all the criteria as a result of the evaluation, the date of application made to the relevant network operator shall be taken as the basis for the ranking.

(7) For applications regarding generation facilities within the scope of the first paragraph of Article 11, a positive connection opinion shall be formed by the relevant network operator, without prejudice to the procedures and principles to be determined by the Authority, without any further action within the scope of this Article.

(8)⁵⁷ Applications found to be complete within the scope of the fourth paragraph of Article 13 shall be evaluated technically by the commission defined in the third paragraph of Article 12, within the first twenty days of the month following the evaluation made in terms of documents. Each application is evaluated independently of the others in terms of connection and system usage, but together in terms of port. The technical evaluation is completed by evaluating the application in terms of the measurement and protection system of the facility planned to be established within the scope of the connectable capacity and short circuit current limit calculations of the relevant transformer station, based on the compliance of the application with this Regulation, the relevant technical legislation and the relevant legislation.

(9)⁵⁸ In the priority assessment conducted within the scope of the sixth paragraph, where a consumption facility or facilities that have previously been issued a connection agreement invitation letter are made subject to a new application, the portion of the electricity consumption amount of such facility or facilities corresponding to the installed capacity of the generation facility previously allocated for that consumption facility shall not be taken into account in the new applications. The reference consumption amount within this scope, forming the basis of the priority assessment specified in subparagraph (b) of the sixth paragraph shall be calculated as follows:

$$\ddot{O}DT = TT \times \left(\frac{TSG - \ddot{U}KG}{TSG} \right)$$

The following definitions shall apply in the implementation of this formula:

$\ddot{O}DT$: The electricity consumption amount forming the basis for the priority assessment;

⁵⁷ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁵⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

TT: Total electricity consumption amount not offset (prior to the offsetting process) of the consumption facility or facilities planned to be associated with the generation facility subject to the application within the last one year;

TSG: Total contractual capacities stated in the connection agreement of the consumption facility or facilities planned to be associated with the generation facility subject to the application;

ÜKG: Total installed capacity of the generation facility or facilities for which a connection agreement invitation letter has previously been issued through association with the relevant consumption facility or facilities.

In applications falling within the scope of subparagraph (h) of the first paragraph of Article 5, where the consumption facility or facilities associated with the generation facility or facilities belong to municipalities, their affiliated entities, industrial facilities, or facilities used for agricultural irrigation purposes, the TSG value used in the formula set out in this paragraph shall be calculated by applying a multiplier of two. However, the double multiplier shall not be applied in cases where the ÜKG is lower than the TSG.

Creation of connection point and issuance of invitation letter to sign connection agreement

ARTICLE 15 – (1) For the applications that are concluded in accordance with the provisions of Article 14;

(a) Results of the evaluation shall be announced on the website of the relevant network operator in a way to include explanations regarding the technical evaluation, within the following day of evaluation date;

(b) A written notification shall be served to the applicant about the result of the evaluations within 3 (three) business days from the date of evaluations results. Written notifications to be served to the persons whose applications were refused shall include the grounds for refusal and technical evaluations and documents shall be returned to the applicants in ten business days after one copy of them is sent to the permanent data custodian;

(c) Persons whose applications were based on hydraulic resources and refused, a notification shall be served to the special provincial administration within five business days from the date of announcement on website;

(ç) TEİAŞ shall be notified within 5 business days about the persons whose application turned negative as a result of the technical evaluation, but TEİAŞ has given a positive opinion on the fault current limit;

(d) Except for applications based on geothermal, biomass, wind or solar energy, if those whose connection application is found suitable make a written application within one month from the announcement date of the list specified in sub-paragraph (a), the invitation letter for the connection agreement shall be notified to the relevant person by the relevant network operator. In this context, positive connection opinions of applicants that do not submit a written request shall become automatically invalid. For the applications based on hydraulic resources, a notification shall be served to the special provincial administration within five days from the date invitation letter to sign connection agreement is notified to the relevant persons.

Creation of connection opinion as a result of technical evaluation and issuance of an invitation letter to connection agreement

ARTICLE 16 – ^{59,60}(1) With respect to the technical evaluation:

⁵⁹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁶⁰ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

a) Among the applications based on geothermal, biomass, wind or solar energy; the information in the technical evaluation form of the applications whose connection applications are found suitable shall be sent to the EİGM by submission through YEPDİS for technical evaluation within ten business days from the date of approval of the application. Technical evaluation shall be concluded by the EİGM within thirty days and technical evaluation report shall be sent to the relevant network operator. In the event of incorrectness and/or incompleteness in the information sent to the EİGM, applicant shall be notified by the relevant network operator to correct the nonconformity within 3 business days from the relevant detection. Without prejudice to the provisions of subparagraph (b) of this paragraph, if the inaccuracy and/or incompleteness is not corrected within 10 business days from the date of notification or if the technical evaluation report as a result of the evaluation of the EİGM is negative, application documents shall be returned to the applicants after one copy of them is sent to the permanent data custodian and the relevant network operator shall update the status in YEPDİS.

b) If, as a result of the technical evaluation conducted by EİGM, an intersection or overlap is determined in power plant sites or an interaction effect between wind turbines is identified, and without prejudice to the provisions of the eighth paragraph of Article 30 and the relevant legislation, the relevant network operators shall grant the applicant the right to file for an amendment request, provided that the modified application fulfils the condition of being connected from the same transformer station for distribution level connections or from the same transmission zone for transmission level connections. Applications project sites of which are changed as a result of this process shall be resubmitted to EİGM for a new technical evaluation.

c) Within the scope of subparagraph (b), if the applicant fails to submit the site change or revision request to the relevant network operator within ninety days following the date of notification issued by the relevant network operator for any reason whatsoever, or if the renewed technical evaluation also results negatively, the application documents shall be returned to the applicant after a copy thereof is transferred to a permanent data storage medium, and the relevant network operator that did not perform the capacity allocation shall notify TEİAŞ accordingly and update the status in YEPDİS.

(2)⁶¹ Invitation letter for the connection agreement issued for the applications based on geothermal, biomass or solar energy, technical evaluation reports of which is positive shall be served to the relevant person by the relevant network operator within one month from the date of announcement of list indicated in the fifth paragraph, upon the written application of the relevant persons. In this context, positive connection opinions of applicants who do not submit are automatically invalidated and application documents shall be returned to the applicants after one copy of them is sent to the permanent data custodian.

(3)⁶² Among wind-energy based applications, technical evaluation reports of applications whose technical evaluation is approved by the EİGM shall be announced on the website of EİGM until fifth day of each month. An application shall be made by the applicant to the relevant unit of TÜBİTAK for technical interaction permit within thirty days from the announcement date. Document certifying that such application has been complete shall be submitted to the EİGM within thirty days from announcement date of the EİGM. If such document certifying that the application has been complete and submitted to the relevant unit of TÜBİTAK;

(a) is not submitted within the statutory period;

(b) is submitted within the statutory period, for the capacity of the relevant application to be held until the result of the technical interaction permit.

⁶¹ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁶² Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

a notification shall be served by the EİGM to the relevant network operator. Technical interaction permit shall be notified to the EİGM by the relevant network operator within ten business days along with technical evaluation report. In the event that the technical evaluation report and/or technical interaction permit is negative or in the event that document certifying that the application has been complete is not submitted within the statutory period, application documents shall be returned to the applicants by the relevant network operator after one copy of them is sent to the permanent data custodian. For wind energy applications, in the event that the technical interaction permit is denied, the applicant shall be granted the right to apply to the relevant network operator within sixty days for a site change or revision, provided that the connection is made from the same transformer station for distribution level connections and from the same transmission zone for transmission level connections. However, if the site change or revision is not submitted to the relevant network operator within sixty days for each change or revision, the application shall be rejected.

(4) Invitation letter to sign connection agreement shall be issued by the relevant network operator for wind-energy based applications whose technical interaction permit and technical evaluation report is positive. Invitation letter to sign connection agreement shall be served by the relevant network operator to relevant persons within one month from the date of announcement of list indicated in the fifth paragraph if such persons submits written request. In this context, positive connection opinions of applicants who do not submit such request shall automatically be invalidated and application documents shall be returned to the applicants after one copy of them is sent to the permanent data custodian.

(5) Information regarding applications that resulted positively or negatively within the scope of the first, second, third and fourth paragraphs shall be announced regularly on a monthly basis on the website of the relevant network operator in a way to include necessary explanations.

(6) The Article of this Regulation that the document is based on shall be explicitly specified in the invitation letter to sign connection agreement issued by the relevant network operator. In this document, it is also specified under which Article the surplus electricity will be evaluated.

Connection agreement application

ARTICLE 17 –(1)^{63,64} Those who are served an invitation letter to sign the connection agreement shall be granted one year from the date of notification of the connection agreement invitation letter. Connection agreement invitation letter recipients shall submit the generation facility project and, if any, the connection line project to the approval of the Ministry or to institutions and/or legal entities authorized by the Ministry, within the aforementioned period.

(2) In the event that the relevant individual or legal entity submits the following documents completely and duly to the relevant network operator within the statutory period specified in the first paragraph, the network operator is obliged to execute a connection agreement with them within thirty days:

(a) Project approvals within the scope of the relevant technical legislation required for the commencement of generation facility construction;

(b) Water usage right agreement for applications based on hydraulic resources.

(c)^{65, 66}

(3)^{67,68}

⁶³ Amended pursuant to the Regulation published in the Official Gazette dated 29 July 2023 and numbered 32263.

⁶⁴ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

⁶⁵ Amended pursuant to the Regulation published in the Official Gazette dated 02 March 2023 and numbered 32120.

⁶⁶ Repealed pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

⁶⁷ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁶⁸ Repealed pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

(4)⁶⁹ In the event that applicants do not submit the said documents to the relevant network operator within the periods designated in the first paragraph relevant individuals and legal entities lose their right to execute connection agreements and submitted documents shall be returned.

(5) Ownership and operating limits for the connection shall be specified in the connection agreement.

(6)⁷⁰ Applications made on integrated parcels or parcels to be associated with the same consumption facility or facilities are evaluated within the scope of enhancement of installed capacity. In the event that enhancement of installed capacity is requested in generation facilities which are entitled to receive invitation letter and executed connection agreement as a result of the applications made as of the effective date of this Regulation, relevant request shall be evaluated together with all other applications made in the same month of request. In this context:

(a) ⁷¹ Where the commission gives negative opinion to the said request, the validity of the connection agreement and the invitation letter to the existing connection agreement of the applicant continues;

(b) ^{72,73} In case of a request for an increase in installed capacity for the generation facilities for which an invitation letter to the connection agreement is given and a positive opinion is given by the commission to the said request, an additional period of ninety days shall be given in addition to the periods specified in the first paragraph in order to complete the obligations under the second paragraph from the date the invitation letter to the revised connection agreement within the scope of power increase is notified to the applicant;

(c) ^{74,75} In case of a request for an increase in the installed capacity at the generation facilities that have signed a connection agreement and whose acceptance has not been completed and a positive opinion is given by the commission, from the date of notification of the invitation letter to the applicant for the revised connection agreement within the scope of power increase, an year shall be given for the completion of the obligations under the second paragraph of the invitation letter for the revised connection agreement. In the event that the revised connection agreement is signed, a period of one year shall be granted to complete acceptance procedures related to the power increase from the date of the revised connection agreement. If the period granted for completing the acceptance procedures related to the power increase is less than the remaining period for accepting the existing connection agreement prior to the power increase, the remaining period for completing the acceptance of the generation facility shall be taken as the basis for completing the acceptance of the power increase.

ç)⁷⁶ If a request for an increase in installed capacity is made for generation facilities where acceptance procedures have been completed and the commission issues a positive opinion on the request, a period of one year shall be granted to fulfill the obligations under the second paragraph regarding the revised connection agreement invitation letter. In the event that the revised connection agreement is signed, a one year period is granted to complete the acceptance procedures related to the power increase from the date of the revised connection agreement.

d)⁷⁷ Regarding the power increase applications covered by this paragraph; in the event that the relevant individuals or legal entities fail to submit the relevant documents to the network

⁶⁹ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

⁷⁰ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁷¹ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁷² Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁷³ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁷⁴ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁷⁵ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁷⁶ Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁷⁷ Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

operator within the period specified in the connection agreement invitation letter, they shall lose the right to sign a connection agreement for the power increase, and the validity of the existing connection agreement invitation letter prior to the power increase and, where applicable, the connection agreement shall continue to remain in effect.

e)⁷⁸ In the event that the acceptance procedures for the production facility covered by the additional power increase are not completed within the period specified for the acceptance of the power increase, the connection agreement invitation letter for the power increase, the connection agreement, and the allocated capacity shall automatically become invalid, and the invitation letter to the connection agreement and the connection agreement prior to the power increase shall remain valid. If the invitation letter and connection agreement for the existing connection agreement prior to the power increase are canceled for any reason, the invitation letter and connection agreement for the revised connection agreement subject to the power increase shall become invalid.

(7)⁷⁹ For generation facilities that became eligible to receive a connection agreement invitation letter before 12/05/2019, the requested increase in mechanical installed capacity cannot exceed twenty percent of the electrical installed capacity. For generation facilities that became eligible to receive a connection agreement invitation letter after 12/05/2019, the requested mechanical installed capacity cannot exceed twice the electrical installed capacity.

Compliance, maintenance, tests and acceptance

ARTICLE 18 – (1)⁸⁰ Individual or legal entity establishing a generation facility within the scope of this Regulation; shall notify the relevant network operator that the generation facility to be connected to the network complies with the criteria defined in this Regulation and the conditions included in the connection agreement. It shall be written down in a minute and signed by the relevant network operator within fifteen days that the generation facility is ready for the acceptance. Application for acceptance shall be made by submitting such minute to the Ministry or institutions and/or legal entities authorized by the Ministry.

(2) Acceptance procedures are carried out in accordance with the relevant technical legislation.

(3)⁸¹ Regarding acceptance process and transactions; no charge will be requested for the electricity supplied to the network during the pre-acceptance, acceptance transactions and test transactions phases. Energy supplied during these phases shall be deemed to have been generated and transmitted to the system by the relevant assigned supply company and is considered as free contribution to YEKDEM.

(4)⁸² Where generation and consumption facilities are not located in the same metering point; the amount of internal consumption that will occur due to the operation of all kinds of structures and equipment in the generation facility area before acceptance, during the acceptance process and during the testing process is included in the set-off by being added to the consumption of the consumption facility or facilities associated with the generation facility in the first billing period after the generation facility is put into operation.

Commissioning of generation facilities and system usage

ARTICLE 19 – (1)^{83,84} It is obligatory to complete the procedures for obtaining the necessary ÇED, zoning, and other permits and the acceptance procedures required to commence investment in the generation facilities to be connected to the network as per the provisions of

⁷⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁷⁹ Inserted pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

⁸⁰ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁸¹ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁸² Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁸³ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁸⁴ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

this Regulation, starting from the signing date of the connection agreement, within the following periods, without prejudice to seventh paragraph of Article 30;

(a) one year for all generation facilities that use the distribution transformer pertaining to the relevant network operator;

(b) among the generation facilities that do not use the distribution transformer pertaining to the relevant network operator;

(1) three years for generation facilities based on hydraulic resources;

(2) two years for generation facilities based on other resources;

(c) ⁸⁵ For generation facilities to be connected to the transmission network, the period stipulated for generation facilities with the same qualifications within the framework of the Electricity Market Licensing Regulation published in the Official Gazette dated 2/11/2013 and numbered 28809,

(ç)⁸⁶ all generation facilities covered by subparagraph (h) of the first paragraph of Article 5 must be completed within three years.

The above stated periods shall be included in the connection agreement to be signed after the date of entry into force of this Article. In the event that the generation facilities are not completed until end of such periods, licenses related to connection agreement, allocated capacity, technical interaction permit and water usage rights shall automatically become invalid, save for the events of force majeure referred to in Article 35 of Electricity Market Licensing Regulation and cases that are deemed appropriate by the Board. In unlicensed generation facilities, a single acceptance can be made, except for power increase procedures carried out within the scope of the sixth paragraph of Article 17. However, partial acceptance may also be made, provided that each acceptance is not less than 10 MWe. However, in the event that the remaining capacity outside the accepted part is not accepted within the specified timeframe, the relevant connection agreement shall be updated based on the accepted part.

(2) Generation facilities may supply energy to the system as of the date specified in the system usage agreement. Such date can by no means be before the date generation facility starts business.

(3)⁸⁷ In generation facilities that are accepted and put into operation, parties are obliged to sign a system usage agreement within one month following the start of commercial activity of the facility. In the event that system usage agreement is not executed by the owner of generation facility within one month, generation facility shall be separated from the network without requiring any further notification until generation facility is made appropriate and grounds for the separation shall be notified to the owner of the generation facility in writing within 3 (three) business days.

(4)⁸⁸ In generation facilities that have been accepted and put into operation, if the system usage agreement is not signed by the parties within one month following the date the facility commenced commercial operations, the energy produced during the period until the relevant network operator disconnects the generation facility from the network shall be considered as a free contribution to YEKDEM, assuming that it was produced by the assigned supply company and fed into the system. The system usage fee arising for the amount of energy considered as a free contribution to YEKDEM under this paragraph shall be paid to the relevant network operator through the assigned supply company, and no invoice shall be issued to the owners of unlicensed generation facilities for the energy considered as a free contribution to YEKDEM.

Issuing generation source certificate to unlicensed generators

⁸⁵ Amended pursuant to the Regulation published in the Official Gazette dated 02 March 2023 and numbered 32120.

⁸⁶ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

⁸⁷ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁸⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

ARTICLE 20 – (1) Upon their request, generators who executed connection agreement and system usage agreement with relevant network operator for the purpose of generating electricity from renewable energy resources within the scope of this Regulation shall be issued a Generation Source Certificate in accordance with the sample in Annex-2 by the relevant network operator.

(2) Applications to be made within the scope of this Article shall be concluded within ten business days at the latest. Generation Source Certificate can be issued only once by the relevant network operator for the same invoicing period within the scope of this Article.

Meters, remote monitoring, protection and control systems

ARTICLE 21 – (1) For the purpose of application of this Regulation, save for the provisions of third paragraph;

(a) If the consumption and generation facilities are located in the same place, bidirectional meter that will enable communication required by the legislation for the settlement mechanism to the place specified in the connection agreement;

(b) ⁸⁹ If the consumption and generation facilities are not located in the same place, bidirectional meter for generation facility and one-way meter for consumption facility that will enable communication required by the legislation for the settlement mechanism to the place specified in the connection agreement shall be installed. For bidirectional meters, a second counter can be installed by the network operator for control purposes.

(2) Metering point forming the basis of invoicing is the meter to be installed to the network on the connection point in accordance with the first paragraph. It is compulsory to have a separate meter to measure generation of each generation facility connected to the network and the daily data to be obtained from such meter shall be submitted by the relevant persons in accordance with the format requirements designated by the Authority.

(3)⁹⁰ Meters installed in accordance with the first paragraph to the generation facilities whose installed capacity is higher than 10 kW shall comply with the automatic metering system to be established in accordance with the relevant legislation. Meters installed to the generation facilities whose installed capacity is higher than 10 kW shall be associated to the metering and communication system.

(4) Meter enabling the separate hourly measurement of electricity generated in the micro-generation facilities and cogeneration facilities and generation facilities based on the renewable energy to be established for a consumption facility and subject to different price incentives.

(5)⁹¹ Meters within the scope of this Article shall be procured and installed by the relevant distribution network operator for generation facilities to be connected to the distribution system. For generation facilities to be connected to the transmission system, the meters to be installed at the metering points located within the boundaries of a user's property shall be procured by the user and installed by TEİAŞ.

(6) During the acceptance stage of generation facility, metering system shall be sealed and recorded after the control in a way to include the meter installed within the scope of the second paragraph as well by the officer of the relevant network operator.

(7)⁹² Connection to SCADA control center that belong to the network operator to which the generation facilities whose installed capacity is equal to and higher than 50kW shall be made in accordance with the Electricity Network Regulation. Individuals and legal entities shall procure and establish required equipment and infrastructure for the generating facility.

⁸⁹ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁹⁰ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

⁹¹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁹² Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

Operation

ARTICLE 22 – ⁹³(1) Generation facility cannot be operated with power more than the contract power set out in the connection and/or system usage agreement. In the event that the generation facility is operated with power more than the contract power set out in the connection and/or system usage agreement, penalty clauses included in the Connection Agreement to the Distribution System for Unlicensed Electricity Generators shall apply for generators connected to the distribution system; whereas penalty clauses included in the transmission system System Usage Agreement shall apply for generators connected to the transmission system.

(2)⁹⁴ The interruption to the connection of the generation facility under the necessary circumstances shall be realized pursuant to Article 27 of the Electricity Market Connection and System Usage Regulation.

Determination of surplus electricity energy

ARTICLE 23 – (1) In principle, individuals and legal entities engaged in unlicensed generation shall generate electricity for the purpose of meeting their own needs. However, the amount of electricity generated in the generation facilities referred to in sub-paragraphs (c), (d), (e), (f) and (g) of the first paragraph of Article 5 and that cannot be consumed in the consumption facility or facilities established at the same location, may be consumed in another consumption facility or facilities owned by the same person provided that they are located in the same distribution region.

(2) Surplus electricity generated by individuals and legal entities within the scope of this Regulation and transmitted to the network shall be detected by the relevant network operator;

(a) On an hourly basis from the data obtained from the meter installed to the place specified in the connection agreement if the generation facility and the consumption facility are located in the same place and/or;

(b) On an hourly basis to be calculated by offsetting hourly consumption data related to the consumption facility or from data to be obtained by using profile application approved in accordance with the relevant legislation governing balancing and settlement transactions, from hourly rates obtained from generation meter for the facilities that it is not possible to obtain hourly data from consumption meters for hourly consumption if the generation facility and the consumption facility are not located in the same place.

(3) Relevant network operator shall detect the amount of surplus electricity for each generator transmitted to the network for each invoicing period by gathering hourly data obtained on the source basis in accordance with the second paragraph and notify the relevant assigned supply company until the sixth day of each month.

(4) Relevant network operators shall notify the market operator of the amount of surplus electricity by the unlicensed generators in its network:

(a) On the source basis for the unlicensed generators within the scope of the first paragraph of Article 24;

(b) For the unlicensed generators within the scope of the second, third, fourth and fifth paragraphs of Article 24;

(c) Separately through Market Management System the total amounts each month on an hourly basis in compliance with the issued schedule related to the notification of meter values in the drafting unit configurations forming the basis of settlement in the relevant provisions of legislation providing the settlement transactions for other cases where such amounts are to be considered as free contribution to the YEKDEM within the scope of this regulation and relevant legislation.

⁹³ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁹⁴ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

(5) In the event that consumption facility associated with the unlicensed generation facility supplies energy as an eligible consumer through a bilateral agreement, the value calculated by offsetting the generation within the scope of unlicensed generation and consumption shall be inserted in place of the value measured by the meter for the consumption location registered in the Market Management System. In this context, in the event that there are more than one facility associated with the generation facility and they are considered as eligible customers, it is mandatory for all of the consumption facilities to use their right to choose the supplier, and energy supply of all facilities be supplied by the same supplier. In the event that energy supply of all facilities is not supplied by the same supplier, the energy generated in the relevant month is deemed to be generated and transmitted to the system by assigned supply company and no payment shall be made by market operator and assigned supply company due to such energy and energy transmitted to the system shall be regarded as free contribution to YEKDEM in this context.

(6) Energy transmitted to the system from facilities to be established in free zones within the scope of this Regulation can be consumed only within the territories of free zones. In this context, no payment shall be made for the energy transmitted to the system and energy transmitted to the system in this context shall be regarded as free contribution to YEKDEM.

Utilization of surplus energy

ARTICLE 24 – (1) Within the scope of sub-paragraphs (c), (f) and (g) of the first paragraph of Article 5;

(a) The net amount of electrical energy generated in the generation facility or facilities established in the same place with the consumption facility and supplied to the network during each invoicing period;

(b) ⁹⁵ The net amount of electrical energy that cannot be consumed during each invoicing period in the relevant consumption facility from the electricity generated and supplied to the network in the generation facility or facilities not established in the same place with the consumption facility shall be purchased as surplus electricity energy at the price determined by the supplier company for ten years to be determined within the scope of YEKDEM. This period shall be calculated starting from the date when the relevant generation facility starts to supply energy to the network within the framework of the second paragraph of Article 19. As of the end of the ten-year period, the procedures and principles regarding the implementation with regards to these facilities shall be determined by the President in accordance with the second paragraph of Article 6 of the YEK Law.

(2) Within the scope of sub-paragraphs (e) and (f) of the first paragraph of Article 5, the net amount of energy generated by generation facilities established by individuals or legal entities from sources other than renewable energy resources shall be purchased by the assigned supply company at the lowest price determined in the Schedule (I) annexed to the YEK Law for ten years from the date the facility starts to supply energy to the network. The energy supplied to the system shall be evaluated within the scope of the electricity sold to its customers within the scope of the retail sale tariff by the supplier companies.

(3) In the event that the energy is supplied to the network from the generation facilities, which are established within the scope of sub-paragraphs (ç) and (d) of the first paragraph of Article 5, the said energy amount shall be considered within the scope of YEKDEM in accordance with the relevant legislation. However, this energy shall be considered as generated and supplied to the system by the assigned supply company, and no payment shall be made by the market operator and the assigned supply company in relation to this energy, and the energy supplied to the system in this context shall be considered as a free contribution to YEKDEM.

⁹⁵ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

(4) In the event that more than one generation facility based on renewable energy resources other than the ones within the scope of sub-paragraph (ç) of the first paragraph of Article 5 or a generation facility based on renewable energy sources and a micro-cogeneration facility shall be established for a consumption facility and the generation facility which supplies the surplus energy supplied to the network cannot be determined, the energy supplied to the network from these facilities shall be purchased at the lowest price determined according to those that are relevant within the scope of YEKDEM.

(5) In the event that the generation facilities that can be established within the scope of sub-paragraphs (ç) and/or (d) of the first paragraph of Article 5 and generation facilities that can be established within the scope of other sub-paragraphs of the same paragraph are established together and that the generation facility from which the surplus energy supplied to the network cannot be determined, the amount of energy in question shall be evaluated within the scope of YEKDEM in accordance with the relevant legislation. However, this energy shall be considered as generated and supplied to the system by the assigned supply company, and no payment shall be made by the market operator and the assigned supply company in relation to this energy, and the energy supplied to the system in this context shall be considered as a free contribution to YEKDEM.

(6) Electrical energy within the scope of the second paragraph can be sold to consumers who buy energy within the scope of the tariff set by the assigned supply company.

(7) Unlicensed generators cannot enter into bilateral agreements and/or make sales in organized wholesale electricity markets for their generation within the scope of this Regulation.

(8) ^{96,97} In the event that the generation facilities installed within the scope of sub-paragraph (d) of the first paragraph of Article 5 and the generation facilities within the scope of sub-paragraph (h) of the same paragraph are established together, provided that they are at the same or different transmission zone and different metering points, and that no energy is supplied to the grid from the generation facility covered by subparagraph (d) of first paragraph of the Article 5, the surplus energy given to the network after the monthly offsetting shall be evaluated within the scope of YEKDEM at the price determined for unlicensed generation facilities in Schedule (I) attached to the YEK Law in accordance with the relevant legislation.

Payment for and purchase of surplus energy

ARTICLE 25 – (1) The assigned supply company shall perform the following operations respectively in order to calculate the amount of payment to be made to each generator for each invoicing period for the amount of energy that it is required to purchase within the scope of YEKDEM:

(a) It shall determine the amount of payment for the amount of energy that it is required to purchase within the scope of the first paragraph of Article 24 by multiplying the surplus generation to be determined for each generator and notified to itself in accordance with the third paragraph of Article 23 with the price determined in accordance with the first paragraph of Article 24;

(b) According to sub-paragraph (a) of this paragraph, it shall determine the payment to be made for each source by collecting the prices found for each generator on the basis of source;

(c) It shall determine the amount of payment for the amount of energy that it is required to purchase within the scope of the fourth paragraph of Article 24 by multiplying the surplus generation that is determined for each generator and notified to it in accordance with the third paragraph of Article 23 with the lowest price that is relevant;

(ç) It shall determine the total price to be paid to the unlicensed generators to be notified to the market operator (LÜYTOB) for the relevant invoicing period and by collecting the sum

⁹⁶ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁹⁷ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

of the costs determined on the basis of source in accordance with sub-paragraph (b) of this paragraph and the amount determined under sub-paragraph (c);

(d) It shall notify the market operator of the LÜYTOB amount determined in accordance with sub-paragraph (ç) of this paragraph each month through the market management system in accordance with the regulated schedule regarding the notification of the values of the meters included in the supply-draw unit configurations as a basis for settlement in the provisions of the relevant legislation;

(e) ⁹⁸It shall make the payment that it received from the market operator to the relevant generators by the fifth business day of the month following the calendar month in which the payment was made and notify the Authority on whether the payments have been completed within the week following the said date;

(f) ⁹⁹In case of underpayment by the market operator, it shall pay the amount paid to it to the relevant generators until the fifth business day of the month following the calendar month in which the payment was made to it, in order from oldest to newest in view of the issue date of the invoices issued by generators. If there are invoices with the same invoice date, they shall be arranged in ascending order from lowest to highest amount and payment shall be made in order starting from the invoice with the lowest amount to the invoice with the highest amount.

(2) In order to calculate the amount of payment to be made to each generator for the amount of energy that they are required to purchase under the second paragraph of Article 24, the assigned supply companies shall perform the following operations respectively:

(a) It shall determine the payment to be made by multiplying the surplus generation amount specified for each generator and notified to it according to the third paragraph of Article 23 with the lowest price stipulated in the Schedule (I) annexed to the YEK Law;

(b) Within six days following the notification date within the scope of the third paragraph of Article 23, it shall inform the relevant person about the surplus energy amount supplied to the network and the unit price for energy purchase;

(c) It shall deposit the invoice amount to the bank account to be notified by the relevant person within ten business days following the date of notification of the invoice issued by the relevant person to the assigned supply company;

(3) In case the assigned supply company defaults on the payment, the default interest determined in accordance with Article 51 of the Law No. 6183 dated 21/7/1953 on the Procedure for the Collection of Public Receivables shall be applied at twice the rate.

(4) The foreign exchange buying rate to be announced by the Central Bank of the Republic of Turkey on the date that the energy is supplied to the system shall be used for the payments to be made in accordance with the prices in the Schedule (I) of YEK Law by the assigned supply company for the amount of excess energy it is obliged to purchase.

Monthly offsetting application

ARTICLE 26 – (1)¹⁰⁰ The relevant network operator shall determine the amount of electrical energy generated and supplied to the network on an hourly basis from the data measured by the meter installed in the place determined in the connection agreement for the generation facilities based on renewable energy resources that are entitled to receive a letter of invitation to the connection agreement as a result of the applications to be made as of the effective date of this Regulation.

(2) The relevant network operator shall determine the amount of electricity supplied to and obtained from the network on the basis of the invoicing period by gathering the hourly data obtained within the scope of the first paragraph for each generator within the scope of this

⁹⁸ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

⁹⁹ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁰⁰ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

Article, on the basis of subscriber groups and resources and shall notify the relevant supplier company until the sixth day of each month.

(3) The relevant network operators shall notify the total generation and total consumption amount of unlicensed generators in their networks within the scope of this Article, as separate total values calculated on the basis of subscriber groups and resources to the market operator through the Market Management System on an hourly basis every month in accordance with the regulated schedule regarding the notification of the values of the meters included in the settlement supply-draw unit configurations in the provisions of the relevant legislation regulating the settlement procedures.

(4)¹⁰¹ The surplus electricity supplied to the network in every invoicing period as a result of monthly offsetting in the generation facilities established and operated by individuals or legal entities based on renewable energy resources within the scope of sub-paragraphs (c), (f), (g), (ğ), (h), (i) and (i) of the first paragraph of Article 5 and first, second and third paragraphs of Article 11, by meeting the conditions specified under the first paragraph, shall be purchased by the assigned supply company for ten years. This period shall be calculated from the date when the relevant generation facility starts to supply energy to the network within the framework of the second paragraph of Article 19. As of the end of the ten-year period, the procedures and principles regarding the implementation with regards to these facilities shall be determined by the President in accordance with the second paragraph of Article 6 of the YEK Law.

(5) In the event that energy is supplied to the network as a result of monthly offsetting in generation facilities established under sub-paragraph (ç) of the first paragraph of Article 5 pursuant to the conditions specified in the first paragraph, the said energy amount shall be evaluated within the scope of YEKDEM in accordance with the relevant legislation. However, it is accepted that this energy has been generated and supplied to the system by the assigned supply company, and no payment shall be made by the market operator and the assigned supply company in relation to this energy, and the energy supplied to the system in this context shall be considered as a free contribution to YEKDEM.

(6) The assigned supply company shall perform the following procedures respectively in order to calculate the amount of payment to be made to each generator and each supplier subject to this Article during the invoicing period:

(a) It shall determine the payment to be made for the amount of energy that it is required to purchase within the scope of the fourth paragraph by multiplying the amount of generation that is determined for each generator and notified to it according to the third paragraph with the relevant price determined;

(b) It shall determine the payment to be made by calculating the sum of the prices found for each generator according to sub-paragraph (a) of this paragraph on the basis of subscriber groups and resources;

(c) It shall calculate the sum of the fees determined on the basis of subscriber groups and resources in accordance with sub-paragraph (b) of this paragraph and add this amount to LÜYTOB, of which it will notify the market operator during the relevant invoicing period;

(ç) It shall notify the amount determined in accordance with sub-paragraph (c) of this paragraph and added to LÜYTOB to the market operator each month through the market management system in accordance with the regulated schedule regarding the notification of the values of the meters included in the supply-draw unit configurations in the relevant provisions of the legislation;

(d) In cases where the net energy is withdrawn from the system after the monthly offsetting of the generation and consumption amount of each generator, it shall notify the new consumption amount in order to ensure that the transactions arising from the relevant legislation may be carried out;

¹⁰¹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

(e) ¹⁰² In case surplus energy is generated as a result of monthly clearing for the facilities within the scope of the fourth paragraph regarding the payment made by the market operator for the energy supplied to the system, it shall pay the part corresponding to the surplus energy in the payment calculated under sub-paragraph (a) of this paragraph at the latest by the fifth business day of the month following the calendar month it is paid and notify the Authority on whether the payments have been completed;

(f) It shall pay the price calculated according to the subscriber group of the consumption facility in the tariff issued to the relevant suppliers for the amount of the electrical energy drawn from the system that does not exceed the amount of energy supplied to the system regarding the payment made by the market operator for the energy supplied to the system at the latest by the fifth business day of the month following the calendar month it is paid;

(g) ¹⁰³ In case of underpayment by the market operator, it shall pay the amount paid to it to the relevant generators and suppliers until the fifth business day of the month following the calendar month in which the payment was made to it, in order from oldest to newest in view of the issue date of the invoices issued by the said persons. If there are invoices with the same invoice date, they shall be arranged in ascending order from lowest to highest amount and payment shall be made in order starting from the invoice with the lowest amount to the invoice with the highest amount.

(7) In the event that the net energy is withdrawn from the system after the monthly offsetting process, the invoices shall be accrued and collected according to the provisions of the current contract between the supplier and the consumer for the consumption remaining from the consumption paid by the assigned supply company in accordance with sub-paragraph (f) of the sixth paragraph.

(8) ¹⁰⁴

(9) ¹⁰⁵ In the event that generation facility or facilities to be connected to the system through distribution or transmission level are established for the consumption facilities within the scope of sub-paragraphs (ç) and (h) of first paragraph of Article 5, the amount of electrical energy consumed by the consumption facility shall be determined on an hourly basis based on the data obtained from the meter installed at the relevant location pursuant to generated and supplied to the network on an hourly basis from the data obtained from the meter installed in the place determined in the connection agreement and notified by TEİAŞ until the third business day of each month. The work and transactions within the scope this Article shall be carried out by the relevant distribution company and the assigned supply company.

(10) ¹⁰⁶ In the event that the assigned supply company defaults on payment, the default interest determined in accordance with Article 51 of the Law on the Procedure for the Collection of Public Receivables shall be applied at twice the rate.

(11) ¹⁰⁷ The domestic contribution prices in Turkish Lira to be applied to the unlicensed generation facilities that will start operating for the first time as of 30/6/2021 and from which surplus energy supplied to the network will be purchased at a certain price, any update to these prices, the applicable period, and other procedures and principles with regards to the implementation of such shall be determined by the President in accordance with the second paragraph of Article 6/B of the YEK Law.

(12) ¹⁰⁸ In case generation facilit(ies) connected to the system at transmission level are established within the scope of sub-paragraph (h) of the first paragraph of Article 5 for consumption facilities connected to the system at distribution level, the electricity supply

¹⁰² Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁰³ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁰⁴ Repealed pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

¹⁰⁵ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹⁰⁶ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹⁰⁷ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹⁰⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

volumes pertaining to the generation facility shall be determined on an hourly basis based on the data obtained from the meter installed at the location specified in the connection agreement and notified to the relevant distribution company by TEİAŞ until the third business day of each month and the works and transactions that fall within the scope of this Article shall be carried out by the relevant distribution company and the assigned supply company.

(13) ¹⁰⁹In case generation facilit(ies) are established to be connected to the system from within different distribution regions within the scope of sub-paragraph (h) of the first paragraph of Article 5, the electricity withdrawal volumes pertaining to the consumption facilit(ies) and, if any, the supply volumes pertaining to the generation facility located at the same metering point shall be determined on an hourly basis based on the data obtained from the meter installed at the location specified in the connection agreement and notified by the relevant network operator to the relevant assigned supply company or the relevant market operator until the third business day of each month. If multiple generation facilities are intended to be established for one or more consumption facilities within the scope of this Article, generation facilities may also be established within the regions of different assigned supply companies. In case the generation and/or consumption facilities are located within the regions of different distribution or assigned supply companies, the offsetting processes shall be carried out by the market operator.

(14) ^{110,111} In the event that consumption facilities that include generation facilities with generation license and, provided that they are located at different metering points, generation facilities that fall within the scope of sub-paragraph (h) of the first paragraph of Article 5, are established, the consumption volume pertaining to the consumption facility and the surplus energy supplied to the network after the monthly offsetting to be made for the facility established within the scope of sub-paragraph (h) of the first paragraph of Article 5 shall be evaluated within the scope of YEKDEM at the price determined for unlicensed generation facilities in Schedule (I) attached to the YEK Law in accordance with the relevant legislation. For consumption facilities covered by this clause that do not have a consumption subscription, the contract power specified in the connection agreement shall be based on the feed-in power specified in the connection agreements signed for the relevant generation facility.

(15) ¹¹² If generation facilities that fall within the scope of sub-paragraph (ç) of the first paragraph of Article 5 and generation facilities that fall within the scope of sub-paragraph (h) of the first paragraph of Article 5, provided that they are at different metering points, the offsetting processes of which are both carried out in accordance with this Article and are established together, provided that the facility that falls within the scope of sub-paragraph (ç) of the first paragraph of Article 5 is in operation, and if energy is supplied to the network from the facility that falls within the scope of sub-paragraph (h) of the first paragraph of Article 5 as a result of monthly offsetting, then the energy volume in question shall be evaluated within the scope of YEKDEM in accordance with the relevant legislation in line with the procedure specified in the sixth paragraph. The total installed capacity of the generation facilities that fall within the scope of this paragraph may not exceed the total installed capacity to be determined based on the associated consumption facility pursuant to sub-paragraph (h) of the first paragraph of Article 5.

(16) ¹¹³The generation volume that may be sold beyond the auto-consumption requirements of those who are entitled to receive an invitation letter to sign a connection

¹⁰⁹ Amended pursuant to the Regulation published in the Official Gazette dated 1 October 2022 and numbered 31970.

¹¹⁰ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹¹¹ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

¹¹² Amended pursuant to the Regulation published in the Official Gazette dated 12 September 2023 and numbered 32307.

¹¹³ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

agreement in connection with an application made after 12/5/2019 may not exceed the total electricity consumption volume of the associated consumption facility. The energy supplied to the system in excess of this volume shall be considered as a free contribution to YEKDEM. This paragraph shall not apply to generation facilities associated with consumption facilities in the residential subscriber group with an installed capacity of 50 kW and below. The procedures and principles regarding the implementation of this paragraph shall be determined by the Board.

(17)¹¹⁴ The procedures and principles regarding the settlement transactions to be carried out by the market operator in facilities covered by subparagraph (h) of the first paragraph of Article 5 and Article 30, where the generation and/or consumption facilities are located within the boundaries of different distribution or assigned supply company regions, shall be determined by the Board.

Objections

ARTICLE 27 – (1) Individuals or legal entities engaged in generation within the scope of this Regulation may object to the works and transactions carried out by the assigned supply company in accordance with Articles 23, 24, 25 and 26 within three business days from the date of notification of the transaction.

(2) The assigned supply company shall re-examine the transaction subject to the objection within five business days from the date of objection, and shall correct it if necessary, and notify the objector of the outcome.

(3) If the relevant amount and price subject to the payment change, the difference shall be adjusted during the next invoicing period.

Consumption facilities

ARTICLE 28 – ¹¹⁵(1) Without prejudice to the fifth paragraph of Article 5, the energy generated in the generation facility established in a distribution region by individuals and legal entities engaged in unlicensed generation may only be consumed in the consumption facility or facilities within the same distribution region and belonging to the same person. The energy generated in the generation facilities that fall within the scope of sub-paragraph (h) of the first paragraph of Article 5 may be consumed in the consumption facility(ies) owned by the same person without being subject to the requirement of being located in the same distribution region. If it is intended to establish a generation facility for multiple consumption facilities within the scope of this provision and if the consumption volume is greater than the generation volume as a result of the offsetting process, the consumption invoice shall be issued and notified for the portion of consumption volumes pertaining to the associated consumption facilities that could not be set off.

(2) ¹¹⁶ Generation facilities within the OIZ distribution license region may be associated with consumption facilities belonging to the same person outside the OIZ distribution license region. However, without prejudice to the other provisions, a generation facility may be established outside the OIZ distribution license region for a consumption facility located within the OIZ distribution license region.

(3) It is accepted that the generation is primarily consumed at consumption points with high tariffs in the offsetting to be made for the period in which the generation exceeds the consumption of the person who has more than one consumption facility that is not included in the same tariff group and who associates these facilities with the generation facility.

(4) In cases where the generation and consumption facility is not located at the same metering point, the internal consumption amount that will occur due to the operation of all kinds

¹¹⁴ Inserted pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

¹¹⁵ Amended pursuant to the Regulation published in the Official Gazette dated 1 October 2022 and numbered 31970.

¹¹⁶ Amended pursuant to the Regulation published in the Official Gazette dated 1 October 2022 and numbered 31970.

of structures and equipment in the generation facility area of the generation facility shall be included in the offsetting by adding it to the consumption of the consumption facility or facilities associated with the generation facility.

(5)^{117, 118} If the subscription for the consumption facility or facilities associated with the generation facility is sought to be changed;

a) The total contract power specified in the connection agreement of the new consumption facility or facilities to be associated with the generation facility cannot be less than the installed capacity of the generation facility to be associated; and

b) In the event that persons who have been issued an invitation letter and have signed a connection agreement based on the priority assessment conducted pursuant to subparagraph (b) of the paragraph 6 of Article 14 request to change the subscription for the consumption facility or facilities linked to the generation facility, the total annual electricity consumption of the new consumption facility or facilities to be associated cannot be less than the reference consumption amount taken as the basis for the original application.

In the event that the consumption facility or facilities associated with the generation facility are changed without the knowledge of the relevant network operator and/or the relevant consumption facility or facilities do not fulfill the obligations in subparagraphs (a) and (b), no payment shall be made by the market operator and the assigned supply company regarding this energy and the energy supplied to the system in this context is considered as a free contribution to YEKDEM considering that the energy generated in the relevant period was generated by the assigned supply company and supplied to the system. In the event that the required documents for the transactions related to the consumption facility changes are complete and full, the transactions shall be concluded by the assigned supply company and distribution company simultaneously on the same day as a result of the requests submitted on the last business day of each month.

(6)¹¹⁹

(7)¹²⁰ If unauthorized electricity consumption is detected at the consumption facility or facilities associated with a generation facility owned by individuals or legal entities holding a connection agreement invitation letter or who have signed a connection agreement under this Regulation, specific measures apply. For the relevant period and the subsequent six billing periods, it shall be deemed that the energy produced by the generation facility, proportional to the ratio of the contract power of the consumption facility where unauthorized consumption was detected at the time of detection to the total contract power of all associated consumption facilities, has been generated by the assigned supply company and delivered to the system. No payment shall be made for the energy corresponding to this proportion by the market operator or the assigned supply company during the period specified in this paragraph, and the energy delivered to the system under this scope shall be considered as a free contribution to YEKDEM.

(8)^{121, 122} Without prejudice to the provisions of subparagraph (b) of the fifth paragraph, with respect to generation facilities whose acceptance procedures have been completed and which have entered into operation, in the event that the contract power specified in the connection agreement made for consumption for any of the consumption facility or facilities associated with the generation facility falls below the installed capacity of the generation facility, it shall be accepted that the energy generated for the relevant period is generated and supplied to the system by the assigned supply company and no payment shall be made by the

¹¹⁷ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹¹⁸ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

¹¹⁹ Repealed pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

¹²⁰ Amended pursuant to the Regulation published in the Official Gazette dated 17 December 2024 and numbered 32755.

¹²¹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹²² Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

market operator and the assigned supply company regarding this energy and the energy supplied to the system in this context, and it shall be considered as a free contribution to YEKDEM.

(9)¹²³ As for generation facilities that are accepted and commissioned, in the event that there is no electricity consumption in the consumption facility or facilities associated with the generation facility, save for force majeure events, it shall be accepted that the energy generated for the relevant month is generated and supplied to the system by the assigned supply company, whereby no payment shall be made by the market operator and the assigned supply company regarding this energy, and the energy supplied to the system within this scope shall be considered as a free contribution to YEKDEM.

(10)¹²⁴ All consumption facilities that are associated with unlicensed generation facilities shall consume energy at the latest by the acceptance date of the relevant generation facility. In the event that the consumption facility or facilities do not consume energy as of the acceptance date of the relevant generation facility, it shall be accepted that the energy generated until the consumption is generated and supplied to the system by the assigned supply company and no payment shall be made by the market operator and the assigned supply company regarding this energy supplied to the system in this context, and it shall be considered as a free contribution to YEKDEM.

Consumption unification

ARTICLE 29 ¹²⁵ – (1) Facilities that belong to one or more individuals and/or legal entities whose electrical energy consumption may be measured by a single common meter may combine their consumption for the consumed electricity and establish generation facilities or facilities within the scope of this Regulation.

(2) A written application shall be submitted to the relevant network operator for consumption unification.

(3) Persons who unify their consumption within the scope of this Regulation shall settle any dispute arising from this unification among themselves. No dispute can be directed to the relevant network operator and/or assigned supply company.

(4) According to the Zoning Law dated 3/5/1985 and numbered 3194, consumption unification may occur within the framework of the consumption unification provisions of the approved zoning project in the buildings constructed within the scope of a single construction license.

(5) In the generation facilities established through the renewable energy generation cooperatives established within the scope of the Cooperatives Law No. 1163 dated 24/4/1969, the legal entity of the cooperative may be authorized to handle the work and transactions within the scope of this Regulation.

Applications for consumption needs

ARTICLE 30 – (1)¹²⁶ A generation facility based on renewable energy resources may be established within the scope of sub-paragraph (h) of the first paragraph of Article 5 in order to meet the electricity need of the consumption facilities. In addition, a generation facility based on renewable energy sources may also be established public institutions and organizations within the scope of sub-paragraph (c) of the first paragraph of Article 5. Also, a generation facility may be established in a different distribution region within the scope of sub-paragraph (h) of the first paragraph of Article 5.

¹²³ Amended pursuant to the Regulation published in the Official Gazette dated 31 October 2021 and numbered 31645.

¹²⁴ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹²⁵ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹²⁶ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

(2) ¹²⁷For the facilities within the scope of this Article, the generation and consumption facilities are not required to be at the same metering point.

(3) In the generation facilities established within the scope of this Article, a transaction shall be established within the scope of the fourth paragraph of Article 26 for the surplus energy supplied to the network during each invoice period.

(4) ¹²⁸

(5) ¹²⁹In the event that there are more than one consumption facility associated with the generation facility within the scope of this Article, it is required that all of the consumption facilities use the right to choose the supplier and the energy supply of all facilities must be met from a single supplier for eligible consumers. In cases where the energy supply of all facilities is not covered by a single supplier, the costs are collected by the relevant suppliers by accruing an invoice for consumption in accordance with the contract or bilateral agreement between the supplier and the consumer, without monthly offsetting. It shall be accepted that the energy generated within the relevant period was generated and supplied to the system by the responsible supplier company and no payment shall be made by the market operator and the assigned supply company regarding this energy and the energy supplied to the system in this context shall be considered as a free contribution to YEKDEM. This paragraph shall not apply to consumption facilities that do not exercise their eligible consumer rights and procure electricity from the assigned supply company.

(6) The consumption facilities to be associated with the generation facility covered by this Article must be in the same tariff group.

(7) ^{130,131}Within the scope of this Article and according to the provisions of this Regulation, the acceptance procedures of the generation facilities to be connected to the network must be completed within three years from the signing date of the connection agreement. Except for the force majeure causes stated under the Article 35 of the Electricity Market Licensing Regulation and the cases approved by the Board, if the generation facility is not completed at the end of this period, the connection agreement and the permit documents regarding water usage rights shall be automatically void. In unlicensed generation facilities, a single acceptance can be made, except for the power increase procedures carried out within the scope of the sixth paragraph of Article 17. However, partial acceptance may also be made, provided that each acceptance is not less than 10 MWe. In the event that, the remaining capacity, other than the part that has been accepted, is not accepted within the designated period, the relevant connection agreement shall be updated based on the part that has been accepted.

(8) ¹³² If an unlicensed electricity generation facility is established to be located in the same facility area as licensed generation facilities and to be connected to the same metering point; the connection and system usage agreements pertaining to the relevant generation facilities shall be zero on the feed outside. In case of energy flow to the network from the generation facilities that fall within the scope of this paragraph, the energy in question shall not be subject to any settlement and offsetting within the scope of the relevant legislation and the energy supplied to the system shall be taken into account as a free contribution to YEKDEM.

Inspection

ARTICLE 31 – (1) Within the scope of this Regulation, the inspection and control of the activities of individuals or legal entities engaged in unlicensed generation within the scope

¹²⁷ Amended pursuant to the Regulation published in the Official Gazette dated 1 October 2022 and numbered 31970

¹²⁸ Repealed pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

¹²⁹ Amended pursuant to the Regulation published in the Official Gazette dated 1 October 2022 and numbered 31970

¹³⁰ Amended pursuant to the Regulation published in the Official Gazette dated 02 March 2023 and numbered 32120.

¹³¹ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

¹³² Inserted pursuant to the Regulation published in the Official Gazette dated 02 March 2023 and numbered 32120.

of this Regulation shall be carried out directly or by the Institution through reports prepared by the relevant network operator and/or the assigned supply company.

Expropriation

ARTICLE 32 – (1) For the generation facilities to be established within the scope of this Regulation, no action shall be taken by the Institution regarding the acquisition of immovable ownership and limited real rights.

Collection and preservation of information

ARTICLE 33 – (1) Individuals or legal entities establishing generation facilities within the scope of this Regulation, are required to provide the information and documents requested by the Institution, the relevant network operator and the assigned supply company within the framework of this Regulation within the time limit.

(2) The relevant network operators are provide the following information each month;

(a) The individuals or legal entities whose generation application has been accepted or rejected;

(b) The individuals or legal entities that start to manage generation facility and installed capacity, generation amount, source type, voltage level and generation technology of these facilities;

(c) The city and district where the generation facility is located, and;

(ç) Other information required by the Institution to the Institution in accordance with the format to be determined by the Institution within the scope of this Regulation of the previous month.

(3) Announcements published on the website of the relevant network operators within the scope of this Regulation are systematically archived in their website on a monthly basis for each year.

(4) The relevant network operators and assigned supply companies are required to store and protect the information that they possess in accordance with the provisions of this Regulation by transferring them to the permanent data storage.

Prohibitions and sanctions

ARTICLE 34 – (1) Relevant network operators and assigned supply companies shall not discriminate between individuals or legal entities operating within the scope of this Regulation.

(2) The generation facilities covered by this Regulation cannot be a balancing unit within the scope of the relevant legislation and cannot participate in practices within this scope.

(3) Electricity generated in the generation facilities within the scope of this Regulation cannot be subject to trade, except for the exceptions specified in this Regulation.

(4) Except for the exceptions and arrangements defined in this Regulation the invitation letter for the connection agreement or the connection and/or the system usage agreement shall be canceled without any notification in the event that it is determined that the works and transactions that cannot be corrected due to the nature of the breach are carried out, the conditions that constitute the basis for the application for unlicensed generation no longer exist, these conditions do not exist since the beginning or there is fraud or false statement against the law and legislation in the requests and transactions.

Transfer of generation facility

ARTICLE 35 – (1)¹³³ Provided that it has been accepted, the generation facility within the scope of this Regulation may be transferred to an individual or legal entity who seek to

¹³³ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

generate in accordance with the conditions that meet the capacity allocation, including the conditions arising from the status of the person who wants to transfer within the scope of this Regulation or the relevant legislation, by sale, transfer or other such arrangement Except for the generation facilities included in the first paragraph of Article 11, generation facilities that have not been accepted cannot be subject to transfer under this paragraph.

(2) Individuals or legal entities who will transfer and take over the generation facility within the scope of the first paragraph shall simultaneously apply to the relevant network operator within the first ten days of the month before the transfer process takes place. The relevant network operator shall finalize the applications made within the scope of this paragraph, provided that the documents required for the transfer are whole and complete at the end of the invoicing period and shall notify the supplier company in charge. The transfer process shall not become valid before the relevant network operator unless the individual or legal entity who will take over signs the connection agreement and system usage agreement. Provided that the application is not full and complete, the request shall not be taken into consideration by the relevant network operators and the addressee shall be notified of the deficiencies within 5 business days.

Prices

ARTICLE 36 – (1) ¹³⁴Available capacity fee shall not be accrued for generation facilities that fall within the scope of this Regulation.

(2) Within the scope of this Regulation;

(a) Application fee that can be collected by the relevant network operator;

(b) Annual operating fee that the relevant network operator and assigned supply companies can collect in return for the works and transactions they perform for the people who actually generate within the scope of this Regulation;

(c) The transaction fee for the applications to be made to the relevant network operator and assigned supplier companies and the finalized requests shall be determined by the Board, each year until 31 December, separately for the relevant network operator and the assigned supplier company. The costs that the generation facilities are obliged to pay in accordance with the relevant legislation are reserved. Considering the number of months the generation facility is in operation, annual operating fee for the year the generation facility is in operation shall be paid to the relevant network operator and the assigned supplier company until the end of the last business day in the months of July and December of each calendar year that the generation facility is in operation.

(3)¹³⁵ Individuals or legal entities engaged in generation within the scope of this Regulation are obliged to pay the system usage fees determined by the Board Decision. In the event that the system usage fees are not paid by the unlicensed generation facility owner by the deadline specified in the invoice, the generation facility shall be disconnected from the network by the relevant network operator, without the need for any notification, until the situation becomes appropriate, and the reason for leaving shall be notified in writing to the generation facility owner within three business days.

(4) The provisions of the relevant legislation shall be applied to the individuals or legal entities operating within the scope of this Regulation for all kinds of fees and guarantees arising from the connection and system usage, except for the matters specified in this Regulation.

Other provisions

ARTICLE 37 – (1) The Institution is authorized to carry out sub-regulatory transactions arising from the connection of unlicensed electricity generation facilities to the

¹³⁴ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹³⁵ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

system, system usage and, use and the rights and obligations arising from unlicensed electricity generation and the issues not regulated in this Regulation and the implementation of this Regulation regarding the operation of the network in accordance with the safety, technical and quality principles stipulated in the relevant legislation.

(2) The applicant legal entities shall notify the relevant network operator of any changes to their trade name and type. The connection agreement and/or system usage agreement shall be amended according to the new trade name based on the notification to be made within 15 days.

(3)¹³⁶ Except for facilities that have received partial approval under the first paragraph of Article 19 and the seventh paragraph of Article 30 of this Regulation, persons to whom a letter of invitation to the connection agreement has been issued may, upon request, deduct at most ten percent from the installed capacity included in the connection agreement and the invitation letter for the connection agreement for once.

(4) The electrical energy that is generated by the emergency generator and supplied to the network shall be deducted from the relevant common consumption meter values in order to prevent the accrual of surplus electrical energy at residential estates, shopping centers campuses and similar usage points where the emergency generators which are installed to provide electrical energy to more than one user provide energy to their users through the network disconnected from the main network in case of an outage and where this energy passes through the user meters. Provided that the generation within the scope of this paragraph exceeds the common consumption, the balance shall be transferred to the next month for generation offset. The emergency generator within the scope of this paragraph is connected to the installation via a separate measurement system or a common consumption meter. In both cases, a meter capable of one way measurement shall be installed.

(5) Persons who own generation facilities on wind energy under construction or operation within the scope of this Regulation are obliged to fulfill the requested measures regarding the Communications, Navigation and Radar Systems operated under the responsibility of the General Staff and/or the turbines that are found to have an effect on the systems operated under the responsibility of the MIT in cases of crisis, tension and war situations, when requested by the General Staff and/or MIT.

(6)¹³⁷ Materials used in the power generation facility and connection equipment to be established within the scope of this Regulation must be manufactured in accordance with the relevant legislation and standards, within the scope of warranty and within the last five years. The five-year condition included in the provision of this paragraph does not apply to facilities under sub-paragraph (d) of the first paragraph of Article 5.

(7)^{138,139,140} For wind or solar energy based power generation facilities falling under subparagraph (c) of the paragraph 1 of Article 5; in the event that the legal entity who owns an unlicensed generation facility wishes to merge under its own legal entity or merge within another legal entity with all its assets and liabilities, the merger shall be carried out within the scope of the applicable legislation, provided that all of the relevant generation facility or facilities have been accepted and the relevant network operator shall notify the assigned supply company in writing within five business days following the submission of documents related to the processing of merger or division information. In case where the legal entity owning an unlicensed generation facility remains the same and the share percentages do not change, the condition for acceptance shall not be sought. Legal entities owning unlicensed generation

¹³⁶ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

¹³⁷ Amended pursuant to the Regulation published in the Official Gazette dated 23 September 2020 and numbered 31523.

¹³⁸ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹³⁹ Amended pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

¹⁴⁰ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

facilities shall notify the relevant network operator of the merger and connection and system usage agreements shall be signed between the parties.

(8)^{141, 142} For wind or solar energy based power generation facilities falling under subparagraph (c) of the paragraph 1 of Article 5; in the event that a legal entity within the scope of this Regulation seeks to de-merge completely or partially, the de-merger is carried out within the scope of the applicable legislation, provided that all the generation facilities under its responsibility have been accepted. In case where the legal entity owning an unlicensed generation facility remains the same and the share percentages do not change, the condition for acceptance shall not be sought. Legal entities owning unlicensed generation facilities shall notify the relevant network operator of the de-merger and connection and system usage agreements shall be signed between the parties.

(9)¹⁴³ No transfer of shares other than those by inheritance shall occur for energy generation facilities based on wind or solar energy within the scope of the sub-paragraph (c) of the first paragraph of Article 5 from the date of application until the acceptance of all generation facilities subject to application. This provision does not apply to:

(a) Changes in the shareholding structure of the publicly held legal entities and the publicly held legal entity's shareholder shares, limited to the publicly held shares;

(b) Direct or indirect changes in the shareholding structure of the legal entity due to the share changes between the existing partners of the relevant legal entity depending on the use of the pre-emptive rights of the shareholders;

(c) Indirect changes in shareholding due to changes in the partnership structure of the relevant legal entity and the partnership structure of the partners established abroad;

(ç) Direct or indirect changes in the shareholding structure of the relevant legal entity within the scope of the public offering of the shares of the direct or indirect legal entity shareholders of this legal entity and the relevant legal entity;

(d)¹⁴⁴ Direct or indirect changes in shares of the existing partners of the legal entity owning an unlicensed generation facility, which have direct or indirect shares in the partnership structure, in a way that does not create a change of control in the partnership structure of the legal entity owning the unlicensed generation facility;

(e)¹⁴⁵ Direct or indirect shareholding structure changes in the partnership structure of the legal entity owning an unlicensed generation facility as a result of share transfers between spouses and first degree relative-individuals, who have a direct or indirect share in the partnership structure of the said legal entity owning an unlicensed generation facility;

The relevant network operators are required to carry out the necessary checks on whether the shares have been transferred during the signing of the connection agreement and the preparation of the acceptance report. In case of transfer of shares, according to their relevance, the connection agreement and the invitation letter for the connection agreement of the relevant legal entity shall be canceled.

(10) Direct and indirect partners of distribution and assigned supplier companies, legal entities under their control, persons employed in direct or indirect partnerships of these legal entities under the control these individuals cannot apply for wind and solar energy based generation within the scope of this Regulation in the distribution region of the relevant distribution company and in the distribution region where the relevant distribution company is a shareholder.

¹⁴¹ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁴² Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

¹⁴³ Amended pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹⁴⁴ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹⁴⁵ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

(11)¹⁴⁶ The relevant network operators and the relevant supplier companies may transfer the necessary data and information in written or electronic form in order to implement this Regulation or to fulfill the matters requested by the Authority. In cases where communication is necessary, it is obligatory for those concerned to comply with the statutory periods and take the necessary measures to ensure that the transactions specified in the legislation are not disrupted.

(12)¹⁴⁷ For generation facilities for which a connection agreement invitation letter has been issued, a connection agreement has been signed, and acceptance has been completed and the facility has commenced operations, a site change may be made in cases of force majeure by decision of the Board, provided that connections at the distribution level are made from the same transformer station and connections at the transmission level are made from the same transmission zone.

(13)¹⁴⁸ If it is determined that a generation facility has been established and put into operation without undergoing the acceptance procedures, the relevant network operator shall disconnect the generation facility from the network without any further notice. Within sixty days following the determination, all equipment related to the generation facility shall be dismantled and removed from the parcel where the facility is located by the facility owner. If applicable, the connection agreement invitation letter and the connection agreement shall be terminated. The individuals or legal entities who established the generation facility shall be ineligible to apply under this Regulation for a period of three years.

References

ARTICLE 38 – (1) References made to the Regulation on Unlicensed Electricity Generation in the Electricity Market, published in the Official Gazette dated 2/10/2013 and numbered 28783 and Communiqué on the Implementation of the Regulation on Unlicensed Electricity Generation in the Electricity Market published in the Official Gazette dated 2/10/2013 and numbered 28783 shall be deemed to have been made to this Regulation.

Repealed regulation

ARTICLE 39 – (1) The Regulation on Unlicensed Electricity Generation in the Electricity Market published in the Official Gazette dated 2/10/2013 and numbered 28783 has been repealed.

Unification processes

ADDITIONAL ARTICLE 1¹⁴⁹ – (1) Within the scope of existing connection agreement invitation letters, generation facilities based on wind energy belonging to the same person can be unified within the scope of one of the existing connection agreement invitation letters, provided that the substation to which they will be connected does not change.

(2) For the unification process, an application is made to the relevant grid operator together with the information and documents created according to the new power. If the application is found technically appropriate, the provisions of Article 16 shall apply.

(3) The duration of the invitation letter for the connection agreement created for the generation facilities to be unified shall be determined on the basis of the invitation letter for the connection agreement under which it is unified.

(4) An accepted generation facility and an unaccepted generation facility cannot be unified.

¹⁴⁶ Amended pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁴⁷ Inserted pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

¹⁴⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

¹⁴⁹ Inserted pursuant to the Regulation published in the Official Gazette dated 17 December 2024 and numbered 32755.

Participation of unlicensed electricity generation facilities in aggregation activities

ADDITIONAL ARTICLE 2¹⁵⁰ – (1) Unlicensed electricity generation facilities that have completed their ten-year purchase guarantee may participate in the aggregator portfolio of legal entities holding an aggregator license or whose aggregation activity is incorporated into the supply license within the scope of the Aggregation Activity in the Electricity Market Regulation published in the Official Gazette dated 17/12/2024 and numbered 32755.

(2) The determination regarding the surplus electricity energy generated in unlicensed electricity generation facilities within the scope of aggregation activity shall be made by the relevant grid operator. The market participant performing aggregation activity is responsible for the evaluation of the surplus energy and the payments to be made to the individuals or legal entities who owns the unlicensed electricity generation facility for the said energy.

(3) The procedures regarding price and offsetting applied to unlicensed electricity generation facilities shall also apply for the unlicensed electricity generation facilities within the scope of this Article.

(4) Except for the sixth paragraph of Article 24, the duties, authorities and responsibilities defined for the assigned supply companies in this Regulation shall also apply to legal entities engaged in aggregation activities that include unlicensed electricity generation facilities in their portfolio.

Facilities within the scope of sub-paragraph (ç) of Article 5 and first paragraph of Article 11

PROVISIONAL ARTICLE 1 – (1) In the event that an application is made by the concerned parties within 60 (sixty) days from the date of entry into force of this Regulation regarding electricity generation facilities with roof and façade applications for which an invitation letter for a connection agreement has been issued, a connection agreement has been signed, or which have been put into operation after temporary acceptance within the scope of sub-paragraph (ç) of the first paragraph of Article 5 and the first paragraph of Article 11 after 21/6/2018, as of the month following the application, the procedure shall be established in accordance with the provisions of Article 26.

(2) Until the connection and system usage agreements of the generation facilities included within the scope of the first paragraph are terminated and/or cancelled, the provisions of Article 26 shall be applied.

Procedures to be applied to persons for whom a letter of invitation to a connection agreement has been issued within the scope of the repealed regulation

PROVISIONAL ARTICLE 2 – (1) The work and transactions of the persons who are entitled to receive a letter of invitation to the connection agreement within the scope of the regulation repealed by Article 39, those who receive an invitation letter for the connection agreement or who have signed the connection agreement shall continue in accordance with the provisions of this Regulation.

(2) Regarding the requests made by the persons within the scope of the provisions of the first paragraph, after the effective date of this Regulation, a transaction shall be established in accordance with the provisions of this Regulation.

(3) The contract allowing the persons for whom the invitation letter for the connection agreement to be issued within the scope of grants and/or loans provided by public institutions and organizations or international grant programs, including those governed by the regulation repealed by Article 39 and the those included in the components of the European Union Instrument for Pre-Accession shall be entitled to benefit from the grant and/or loan within the

¹⁵⁰ Inserted pursuant to the Regulation published in the Official Gazette dated 17 December 2024 and numbered 32755.

scope of the said grant and/or loan programs shall be submitted to the relevant network operator within seven months following the signing of the connection agreement. In the event that the relevant document is not submitted, the connection agreement shall be canceled.

Unlicensed generation facilities with a subscription for internal consumption

PROVISIONAL ARTICLE 3 – (1) The agreements and contracts signed regarding the consumption of generation facilities for which subscription has been established for the internal consumption amount due to the operation of all kinds of structures and equipment in the generation facility site before the entry into force of this Regulation shall be terminated within 6 months from the date of entry into force of this Article, and the work and transactions regarding the said consumption shall be carried out in accordance with the fourth paragraph of Article 28.

(2) The generation facilities, whose consumption agreements and contracts are not terminated within the periods defined in the first paragraph, shall be disassociated from the network until their situation is made suitable by the relevant network operator without any notification and the reason for disassociation is notified in writing to the owner of the generation facility within 3 (three) business days.

Facilities that can switch to monthly set-off

PROVISIONAL ARTICLE 4¹⁵¹ – (1) In the event that an application is made within sixty days from the effective date of this Article regarding the electricity generation facilities, for which a invitation letter is drawn up to the connection agreement, a connection agreement is signed or the acceptance is completed within the scope of the sub-paragraph (ç) of the first paragraph of Article 5 and the sub-paragraph (c) of the first paragraph of Article 5 with an installed capacity of 10 kW and below before the date of 12/5/2019, the procedure shall be established as of the month following the application in accordance with the provisions of Article 26,

(2) The provisions of Article 26 shall apply until the connection and system usage agreements of the generation facilities included in the scope of the first paragraph are terminated and/or cancelled.

Facilities to be established by legal entities holding OIZ Distribution License

PROVISIONAL ARTICLE 5¹⁵²- (1) Unlicensed generation facilities belonging to the OIZ Distribution License Holder Legal Entity shall be associated with the meters located at the connection points defined under Article 14 of the Regulation on Electricity Market Activities of Organized Industrial Zones published in the Official Gazette dated 14/3/2014 and numbered 28941 and offsetting processes shall be carried out based on these meters.

(2) For generation facilities that fall within the scope of the first paragraph and for which the necessary association procedures have not yet been carried out, the necessary association procedures shall be completed by TEİAŞ or the relevant distribution company until 28/2/2023.

(3) In the generation facilities that fall within the scope of this Article and which have been put into operation upon the completion of the acceptance procedures, action shall be taken in accordance with the relevant legislation in relation to the surplus energy resulting from hourly or monthly offsetting.

Unlicensed generation facilities using pyrolytic gas and pyrolytic oil

¹⁵¹ Inserted pursuant to the Regulation published in the Official Gazette dated 09 May 2021 and numbered 31479.

¹⁵² Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

PROVISIONAL ARTICLE 6¹⁵³ - (1) In the electricity generation facilities where pyrolytic oil and pyrolytic gas (which are by-products resulting from the processing of waste tires) are planned to be used as fuel and for which a connection agreement invitation letter has been issued or a connection agreement has been signed or which is put into operation following completion of the acceptance procedures, it is obligatory as of the effective date of this Article that such fuel is generated in such facility and no other resources are used.

(2) Among the unlicensed generation facilities whose acceptance has been completed, those facilities that do not produce pyrolytic oil and pyrolytic gas in the facility and use other resources shall take the necessary actions to produce the aforementioned fuels in the facility and cease the use of other resources, if any, until 31/8/2023.

Offsetting processes pertaining to applications made from within multiple distribution and/or assigned supply regions

PROVISIONAL ARTICLE 7¹⁵⁴ - (1) In the facilities where transactions are carried out within the scope of Articles 26 and 30, in case the generation and/or consumption facilities are located within the regions of different distribution or assigned supply companies, the necessary infrastructure on how to carry out the offsetting processes shall be prepared by the market operator within 9 (nine)¹⁵⁵ months.

(2)¹⁵⁶ The offsetting processes in relation to generation facilities to be located within the region of a different assigned supply company and shall be applied as of 1/7/2023. If energy is supplied to the network by the generation facilities that are in operation within the scope of this paragraph, the energy supplied to the network shall be deemed to be generated and supplied to the system by the assigned supply company and no payment shall be made by the market operator or the assigned supply company in relation to this energy. The energy supplied to the system within this scope shall be considered as free contribution to YEKDEM and the system usage fee to accrue for the energy volume considered as free contribution to YEKDEM shall be notified to EPIAŞ by the relevant network operators. No invoice shall be issued to the unlicensed generation facility owners for the energy paid to the relevant network operator through the assigned supply company and taken into consideration as a free contribution to YEKDEM.

(3) The offsetting processes regarding the generation facilities that are in operation as of the date of publication of this Regulation or that will enter into operation until 1/7/2023 as well as the consumption facilities that are located within the region of different distribution or assigned supply company shall be carried out by the assigned supply company located within the region where the generation facility is located until 1/7/2023¹⁵⁷.

Installed capacity reduction operations

PROVISIONAL ARTICLE 8¹⁵⁸ - (1) If an application is made within 60 days as of the effective date of this Article by the persons whose generation facility has not yet been accepted and whose offsetting transactions are to be carried out within the scope of Article 26, a one-off reduction of more than ten percent may be made from the installed capacity included in the invitation letter to the connection agreement and the connection agreement.

Actions preceding electronic application and announcement of capacities

¹⁵³ Inserted pursuant to the Regulation published in the Official Gazette dated 11 August 2022 and numbered 31920.

¹⁵⁴ Inserted pursuant to the Regulation published in the Official Gazette dated 1 October 2022 and numbered 31970.

¹⁵⁵ Amended pursuant to the Regulation published in the Official Gazette dated 31 December 2022 and numbered 32060 (5. bis).

¹⁵⁶ Amended pursuant to the Regulation published in the Official Gazette dated 02 March 2023 and numbered 32120.

¹⁵⁷ Amended pursuant to the Regulation published in the Official Gazette dated 31 December 2022 and numbered 32060 (5. bis).

¹⁵⁸ Inserted pursuant to the Regulation published in the Official Gazette dated 02 March 2023 and numbered 32120.

PROVISIONAL ARTICLE 9¹⁵⁹ - (1) No new unlicensed generation application shall be accepted by the relevant network operators from 1/8/2023 until 30/9/2023 in order to determine and publish the capacities to be announced within the scope of the nineteenth and twentieth paragraphs of Article 7 of this Regulation and to carry out the necessary procedures for the preparation of electronic application infrastructure pursuant to the first paragraph of Article 10. The procedures that fall within the scope of this Regulation shall be carried out in the commission meetings to be held during this period for those applications filed until 31/7/2023.

(2) The first of the announcements to be made within the scope of the nineteenth and twentieth paragraphs of Article 7 of this Regulation shall be made in October 2023 and in accordance with the procedure specified in the said paragraphs.

Procedures related to the letter of invitation for the connection agreement

PROVISIONAL ARTICLE 10¹⁶⁰ - (1) The one-year period covered by Article 17 shall also apply to existing connection agreement invitation letters for the remaining period as of the date this article enters into force. However, in the event that this period is less than one hundred and eighty days, the remaining period shall be applied as one hundred and eighty days.

Priority assessment procedures

PROVISIONAL ARTICLE 11¹⁶¹

a) Data related to generation facility or facilities subject to paragraph 5 of Article 10 of this Regulation and related consumption facility or facilities shall be reported to the market operator by the relevant network operators on a monthly basis and kept up to date. The market operator shall store the aforementioned data in a database accessible to the relevant network operators if deemed necessary. The system to be prepared by the market operator for this purpose shall be put into operation on 15/12/2025.

b) Data to be used in the priority assessment calculation under Article 14 of this Regulation shall be reported to the market operator by the relevant network operators on a monthly basis and kept up to date. The market operator shall store the aforementioned data in a database accessible to the relevant network operators if deemed necessary. The system to be prepared by the market operator for this purpose shall be put into operation on 15/12/2025.

Evaluation of applications for integrated parcels

PROVISIONAL ARTICLE 12¹⁶² - (1) As of 12/05/2019, for connection agreements issued in accordance with the provisions of this Regulation, and for facilities planned to be established under the connection agreement but not yet fully approved; applications made on integrated parcels or parcels to be associated with the same consumption facility or facilities shall be considered within the scope of the enhancement of installed capacity upon request by the relevant individuals or legal entities, and the periods specified in the sixth paragraph of Article 17 shall apply in the event that a revised connection agreement invitation letter or revised connection agreement is issued.

Effective date

ARTICLE 40 – (1) This Regulation enters into force on the date of its publication.

Execution

¹⁵⁹ Inserted pursuant to the Regulation published in the Official Gazette dated 29 July 2023 and numbered 32263.

¹⁶⁰ Inserted pursuant to the Regulation published in the Official Gazette dated 14 May 2024 and numbered 32546.

¹⁶¹ Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

¹⁶² Inserted pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.

ARTICLE 41 – (1) The provisions of this Regulation are executed by the President of the Energy Market Regulatory Authority.

	The Official Gazette in which the Regulation was published	
	Date	Number
	12/5/2019	30772
	Official Gazettes in which the Regulations Amending the Regulation were Published	
	Date	Number
	1.	23/9/2020
2.	9/5/2021	31479
3.	31/10/2021	31645
4.	11/8/2022	31920
5.	1/10/2022	31970
6.	31/12/2022	32060 (5. bis)
7.	2/3/2023	32120
8.	29/7/2023	32263
9.	12/9/2023	32307
10.	14/05/2024	32546
11.	17/12/2024	32755
12.	25/11/2025	33088

ANNEX-1

UNLICENSED GENERATION APPLICATION FORM

Information of Applicant	
Name-Surname/Title	
Address	
Telephone	
Fax number	
E-mail Address / Registered Electronic Mail Address	
T.C. Tax I.D. Number / T.C. I.D. Number	
Bank Account Number (IBAN)	
Consumption Facility Individual Code	
Information regarding Generation Facility	
Name of the Facility	
Address	
Geographical Coordinates (UTM 6-ED50)	

Number of Units / Installed Capacity of the Unit			
Installed Capacity of the Facility			
Type of Resource Used			
Type of Application (It shall be specified that the application is made based on the relevant Article/paragraph/sub-paragraph of the Regulation) (e.g. Article 5/1.c, Article 11/1 etc.)			
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Other Information			
All information provided in this form is accurately filled in by myself. In the event of acceptance of my application; I acknowledge and undertake that I will establish the generation facility in compliance with the qualifications specified in this form, during the construction phase I will not carry out any transaction without obtaining required permissions from relevant network operator, violating the information specified in this form, in the event of violation of information provided in this form my application may be cancelled.			
Name-Surname/Title	Signature	Date (Day/Month/Year)	

ANNEX-2

<p>GENERATION RESOURCE CERTIFICATE with the Purpose of Identifying the Type of Resource within the scope of Law on the Utilization of Renewable Energy Resources for the Purpose of Generating Electricity</p>
<p><i>Date of Issuance of the Certificate</i> <i>This document is valid between .../.../201... and .../.../201..</i></p> <p>(CERTIFICATE NO: ...163) /...164/ 00000000...165)</p> <hr/> <hr/>
<p>This document is issued for in accordance with Article 5 of Law on the Utilization of Renewable Energy Resources for the Purpose of Generating Electricity for the generation facility with the below information.</p> <p>Type of renewable resource: Period of generation: Gross electricity energy generation in the period of generation (kWh): Registry Number of the relevant network operator of generation facility: Name of the generation facility: Place of the generation facility: Type of the generation facility: Installed capacity of generation facility: Connection point to the system and voltage level:</p> <p>..... General Manager166</p>

¹⁶³ Short name of the relevant network operator shall be inserted.

¹⁶⁴ Relevant year shall be inserted.

¹⁶⁵ Ordinal number of the issued certificate shall be inserted.

¹⁶⁶ Logo and emblem of the relevant network operator shall be inserted.

ANNEX-3¹⁶⁷**CAPACITY THAT CAN BE ALLOCATED TO A PERSON FOR A CALENDAR YEAR FROM AG LEVEL IN A DISTRIBUTION TRANSFORMER**

Transformer Capacity (t.c.) (kVA)	Total Connectible Capacity (kWe)	Capacity that can be allocated to a person for a calendar year from AG level in a distribution transformer (kWe)
t.c. < 100	t.c. x 0,5	7,5
$100 \leq \text{t.c.} \leq 1000$		t.c. x 0,1
t.c. >1000		100 kWe

¹⁶⁷ Amended pursuant to the Regulation published in the Official Gazette dated 25 November 2025 and numbered 33088.